

SS-177  
Revised 1-71

WEST VIRGINIA  
SEPTIC TANK INSPECTION FORM

Hampshire County Health Department Installation Permit No. ST-14-91-273  
Name of Owner Daniel Sullivan  
Address Clarksville, Md.  
Property Address Peaceful Valley Est. Lot #9

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served vac. cabin No. Water Closets         
Lot Size 2.31 sq. ft. Area suitable for sewage disposal installation        sq. ft.  
Source of Water Supply well No. Lavatories         
No. Bedrooms 2 No. Showers or Tubs        No. Baths         
No. Garbage Grinders 0 No. Automatic Washers 0

SEPTIC TANK

Material concrete tank Length        x Width        x Depth        =        cubic feet  
Liquid Depth        ft. Liquid Capacity 1000 gal.  
Distance to: Dwelling 16' Water Supply 130' Nearest Property Line 160'

SOIL ABSORPTION SYSTEM

Type Drain Line Material plastic Trench Width 24 Inches  
Trench Depth 20 Inches Total Absorption area in Trench Bottom        sq. ft.  
Diameter of Drain Line 10 Inches Type Filter Media         
No. of Drain Lines 3 Depth Filter Media Under Drain Line        Inches  
Length of Each Line 80, 80, 80 ft. Depth Filter Media Over Drain Line        in.  
Distance of Disposal Field to: (a) Dwelling 30'  
(b) Water Supply 140' (c) Nearest Property Line 80'

An inspection of the septic tank system described herein disclosed that said system (MEETS, DOES NOT MEET) the minimum standards established by the West Virginia State Department of Health.

9-21-80  
Date

[Signature]  
Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

