

John C. Johnson
P.O. Box 190
Cherokee, TX 76832
jcjohn@centex.net

WELL INSPECTION

Property Located at:

106 S. Indian Avenue
Cherokee, TX 76832

Pump Installed March 23, 2004. Aermotor T-12-75

¾ HP - 12 gallons per minute

230 volt Franklin Motor

Amps 8.0 to 9.2

Pressure Switch – PSI 30 to 50

Pump is sitting at approximately 140' deep. Static level is unknown. It has 80' PVC casing installed and the PVC is inside a 6" steel casing.

Well is sealed and is prohibited from weather conditions and is easily accessible.

This well meets all acceptable standards.

John C. Johnson, License #4093PKL
December 8, 2006