

WV STATE DEPARTMENT OF HEALTH
Office of Environmental Health Services
ENVIRONMENTAL ENGINEERING DIVISION

So Potomac Valley
Lot 89 SW258

WELL COMPLETION REPORT

Date(s) OCT 9, 85 County Hampshire Permit #: DW-14-9-86-89
Town: Levels Area Name/Location: Levels TURN Left AT 4 WAY STOP - Follow Road TO Bottom of Mt. STAY ON MAIN Rd. INTO Development UNTIL River is on Left of DRV LOT 89
Well Owner: Linda Kendall Address: 8 Valley Park Court
Telephone Number: (301) 253-6905 DAMASCUS, MD 20872
Well Driller: JERRY W. Adams Address: P.O. Box 73
Telephone Number: (304) 298-3280 FORT ASHBY, WV 26719

WELL LOG

DEPTH IN FEET	FORMATIONS: KIND, THICKNESS, AND IF WATER BEARING	REMARKS:
5'	Top Soil - UNConsolidated	Type of Well: <u>D/W</u> Drilling Method: <u>Air Rotary Hammer</u>
8'	SANDY Soil - UNConsolidated	Well Diameter: <u>6 1/8"</u> Casing O.D.: <u>6-5/8"</u>
11'	SAND & GRAVEL - UNConsolidated	Well Depth: <u>100'</u> Date Completed: <u>OCT 9, 85</u>
24'	GRAVEL - UNConsolidated	CASING: Length <u>42</u> Feet Height above ground <u>2</u> Feet
29'	GRAY SHALE - BedRock - Consolidated	☒ Steel <u>GALV</u> ☐ Plastic ☐ Cast Iron
40'	GRAY SHALE - Consolidated - Cement Set Casing	Other _____ Type _____
70'	GRAY SHALE - W/2 GPM - Consolidated	SCREEN
80'	GRAY SHALE - Consolidated	☒ None Installed
93'	GRAY SHALE - Water 22 GPM	Type _____ Diameter _____
100'	GRAY SHALE - Consolidated	Slot/Gauge _____ Length _____
	TEST Well yield - Stopped Drilling OPERATION	Set Between _____ Ft. and _____ Ft.

PUMPING OR BAILING TEST

DETAILS	#1	#2	#3
Static Water Level (Ft. Below Grade)	<u>22</u>		
Pumping Rate (GPM)	<u>24</u>		
Pumping Level (Ft. Below Grade)	<u>90</u>		
Duration of Test (In Hours)	<u>2</u>		
Recovery Time to Static Level (In Hours)	<u>1/2</u>		

WELL HEAD

Pitless Adapter: Type, Make, Etc. To Be Installed AT Later Date
Well Cap: Type, Make, Etc. ROVER CONDUIT-TYPE
Well Seal: Type, Make, Etc. _____
Well Platform: To Be Installed By OWNER
Length _____ Width _____ Thickness _____
Grouting: ☐ Yes ☒ No
All Public Water Supplies must be grouted.

I hereby certify that this well was drilled and constructed under my supervision, in compliance with all requirements of the referenced permit, and that this record is true to the best of my knowledge and belief.

JERRY W. Adams
Name
A & S Pump Co.
Registered Business Name
Jerry W. Adams
Signed

004
Certification No.

10-9-85
Date

SW257



WEST VIRGINIA DEPARTMENT OF HEALTH

PERMIT

OWNER: Linda Kendall and DRILLER: Jerry Adamsare hereby issued a permit to Construct (Construct, Modify or Abandon) a well locatedat Levels, Turn left at 4-way stop Follow road to bottom of mountain. Stay on main road into development until river is on left of drive. lot along river.

in accordance with Chapter 16 Article 1, Section 9 of the Code of West Virginia.

Date Issued Sept. 25, 1985Expires Sept. 25, 1986Permit No. SW-14-9-85-89
Issuing OfficerHampshire

Sanitarian

Title

County Health Department

This permit is not transferable and any change of information submitted in application dated 9-24-85 will automatically render this permit invalid.

THIS PERMIT IS NOT APPLICABLE TO PUBLIC WATER SUPPLIES