




M : NEL-STRUCT

FAX NO. : 715B369344

Jul. 25 2012 11:59AM P1



July 25, 2012

To: Jake Kuester, Westconsin Credit Union

From: Dennis S. Nelson, Nel-Struct, LLC

Re: N12045 280th St., Boyceville, WI 54725

I was able to visit the above-mentioned property on 7-18-12 at 3:00 PM.

The home rests on 8" poured concrete basement walls on 3 sides. The fourth side of the basement is a stud-framed walk out section at grade. The walls look plumb and are in good condition. I was able to inspect the foundation walls from the inside and outside. The walls look good and are structurally sound.

The home meets local building code and construction requirements. The home meets all FHA requirements, and the foundation meets HUD guidelines for manufactured housing dated Sept. 1996. When the basement was installed, it was done in accordance with HUD manufactured home construction and safety standards.

Sincerely,

  
Dennis S. Nelson, P.E.



7-25-12