

STATE OF TEXAS WELL REPORT for Tracking #407396

Owner:	Kaleb Brewer	Owner Well #:	No Data
Address:	71 Eckert Road Willow City, TX 78675	Grid #:	57-35-7
Well Location:	647 Eckert Road Willow City, TX 78675	Latitude:	30° 24' 054.1" N
Well County:	Gillespie	Longitude:	098° 44' 050.5" W
		Elevation:	No Data
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Start Date: **10/6/2015** Drilling End Date: **10/6/2015**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	8.75	0	50
	6.75	50	145
	6	145	185

Drilling Method: **Air Hammer**

Borehole Completion: **Straight Wall**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks & material)</i>
Annular Seal Data:	1	3	Cement 0.5 Bags/Sacks
	3	52	Bentonite 5 Bags/Sacks

Seal Method: **Gravity**

Sealed By: **Driller**

Distance to Property Line (ft.): **80**

Distance to Septic Field or other
concentrated contamination (ft.): **n/a**

Distance to Septic Tank (ft.): **n/a**

Method of Verification: **estimated**

Surface Completion: **Pitless Adapter Used**

Surface Completion by Driller

Water Level: **26.5 ft. below land surface on 2015-10-06** Measurement Method: **Sonic/Radar**

Packers: **Burlap at 52 ft.**

Type of Pump: **No Data**

Well Tests: **Jetted** **Yield: 60 GPM**

Water Quality:	Strata Depth (ft.) No Data	Water Type No Data
----------------	--------------------------------------	------------------------------

Chemical Analysis Made: **Yes**

Did the driller knowingly penetrate any strata which contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **L & L Drilling Co.**
P.O. Box 217
Hye, TX 78635

Driller Name: **Gregory A. Smith** License Number: **1595**

Comments: **water quality 700 TDS, 20 grains hardness**

Lithology:			Casing:						
DESCRIPTION & COLOR OF FORMATION MATERIAL			BLANK PIPE & WELL SCREEN DATA						
Top (ft.)	Bottom (ft.)	Description	Dia (in.)	Type	Material	Sch./Gage	Top (ft.)	Bottom (ft.)	
0	1	brown topsoil							
1	6	brown clay	5	Blank	New Plastic (PVC)	40 0.265	0	73	
6	41	brown & gray sandstone	5	Perforated or Slotted	New Plastic (PVC)	40 0.265	73	147	
41	182	red sandstone							
85	105	water 5 gpm							
105	182	water 55 gpm							
182	185	red granite							

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 463-7880