

17 7/98

INSPECTION TO BE  
PRINTED OR TYPED

STATE OF WEST VIRGINIA

Hardy County HEALTH DEPARTMENT  
ON-SITE SEWAGE DISPOSAL SYSTEM  
INSPECTION FORM

Permit No.: ST-16-05-224

Tax Map: \_\_\_\_\_ Parcel #: \_\_\_\_\_

County Road: \_\_\_\_\_

County: Hardy

Name of Owner: Daniel & Suzanne Orban Installer: Carl Cindy

Address: 2899 Willow Wood Ct. Crofton, MD 21114

Property Location: Trough Rd 1st left after 2nd big power line on left

Type of Facility: Residence Facility is: New ( ☒ ) Existing ( ) Lot Size: 23 Sq. Ft./Acres

Design Loading in gpd/No. Bedrooms: 4 Bdrm Source of Water Supply: Well

SEWAGE TANK COMPONENT

Capacity in Gallons: 1000 Material: Concrete Manufacturer: Jolin

Distances (in feet) of Tank to: Dwelling: 40' Private ( ☒ ) / Public ( ) Water Source: 50' Property Line: 100' +

ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Absorption Trenches ( ) or Bed ( ) Gravelless Pipe ( ), Diameter: \_\_\_\_\_ Inches  
Chamber Soil Absorption Trenches ( ☒ ) or Bed ( )  
Class II Systems: Pumped/Dosed Soil Absorption Trenches ( ) or Bed ( ) Evapotranspiration Trenches ( ) or Bed ( )  
Shallow Soil Absorption Trenches ( ) or Bed ( ) Other: \_\_\_\_\_

No. of Lines: 2 Length (in feet) of Each: 160, 180, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_

Width of Trenches: 18-36 inches/feet Depth to Bottom of Field: 18-36 inches

If Bed, Dimensions (in Feet): \_\_\_\_\_ If Chamber System, Name: Infiltrator, No. of Units: 60

Approved and Adequate Materials Used? Yes ( ☒ ) No ( ) Size Equates to: 1200 Square Feet of Standard Gravel Field.

Distances (in feet) of System to: Dwelling: 40' Private ( ☒ ) / Public ( ) Water Source: 100' + Property Line: 100' +

Remarks: Distance from tank to dwelling is distance from tank to  
cleanout (40'). Home was not built before inspection date.

An inspection indicates that the sewage disposal system described above  
**DOES MEET** ( ☒ ),  
**DOES NOT MEET** ( ),  
**CANNOT BE DETERMINED TO MEET** ( ) the minimum standards established by the West Virginia Bureau of Public Health.

To correct a health hazard, modifications to existing systems may be done to improve part of a system. Such modifications may not be able to be designated as a **does meet** system since inadequate information is known.

Although many factors contribute to the successful functioning of a sewage disposal system, this office recommends water conservation and maintaining an even usage of water throughout the week.

Sketch of Installation with Triangulation or Distance to Specific Landmarks:



Draw Arrow  
toward North

391019954 NJ  
785303126W

Visit Date(s): 11-7-2005

Final Inspection Date: 11-10-2005

Sanitarian: Will Davis / Sent

