

sed 1-71

WEST VIRGINIA
SEPTIC TANK INSPECTION FORM

HARDY CO Health Department Installation Permit No. 577697046

Name of Owner WENDELL A. FUNKHOUSER

Address RT 1, Box 144, BAKER, WV 26801

Property Address PARKER HOLLOW RD, 3 MILES FROM NEEDMORE, WV

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served Home No. Water Closets _____

Lot Size 100 ACRES sq. ft. Area suitable for sewage disposal installation _____ sq. ft.

Source of Water Supply DRILLED WELL No. Lavatories _____

No. Bedrooms 3 No. Showers or Tubs _____ No. Baths _____

No. Garbage Grinders _____ No. Automatic Washers _____

SEPTIC TANK

Material CONCRETE Length _____ x Width _____ x Depth _____ = _____ cubic feet

Liquid Depth _____ ft. Liquid Capacity 1000 gal.

Distance to: Dwelling 70' Water Supply 115' Nearest Property Line >10'

SOIL ABSORPTION SYSTEM

Type Drain Line Material GRAVELLESS Trench Width 24 Inches

Trench Depth 18-24 Inches Total Absorption area in Trench Bottom 750 sq. ft.

Diameter of Drain Line 10 Inches Type Filter Media N/A

No. of Drain Lines 3 Depth Filter Media Under Drain Line N/A Inches

Length of Each Line 50, 100, 100, _____ ft. Depth Filter Media Over Drain Line N/A in.

Distance of Disposal Field to: (a) Dwelling >55'

(b) Water Supply 100' (c) Nearest Property Line >10'

An inspection of the septic tank system described herein disclosed that said system (MEETS) ~~DOES NOT MEET~~ the minimum standards established by the West Virginia State Department of Health.

10-9-97
Date

Lemorne K. Thompson, R.S.
Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

