

County: LLANO GRID # 57-19-2

Street or RFD: FLAG CREEK OAKS, LOT #15

City, State, Zip code: TX -

3) TYPE OF WORK: RECONDITIONING

4) PROPOSED USE: DOMESTIC

If Public Supply well, were plans submitted to the TNRCC?

6) WELL LOG: 96100

DIAMETER OF HOLE

7) DRILLING METHOD:

8) BOREHOLE COMPLETION:

DATE DRILLING:

DIAMETER FROM TO

AIR ROTARY/HAMMER

GRAVEL PACKED

N^

STARTED: 04/12/96

COMPLETED: 04/12/96

IF GRAVEL... FROM 11 FT. TO 44 FT.
FROM FT. TO FT.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
6	N	PVC CASING	+3	39	SCH 40
6	N	PVC, CUSTOM SLOTTED	39	44	

GEOLOGICAL DESCRIPTION:

FROM	TO	DESCRIPTION
0	2	TOPSOIL
2	10	
10	43	GRANITE GRAVEL
43	44	GRANITE-RED

9) CEMENTING DATA:

Cemented from	No. of Sacks Used
0 FT. TO 11 FT.	2
FT. TO FT.	

Method used: GROUT

Cemented by: LYNN HOY

Distance to septic field lines: ft.

Method of verification of above distance:

10) SURFACE COMPLETION:

PITLESS ADAPTER USED

11) WATER LEVEL:

STATIC LEVEL : 14 FT. DATE: 04/12/96

ARTESIAN FLOW: GPM. DATE:

12) PACKERS: TYPE DEPTH

13) TYPE PUMP:

SUBMERSIBLE

DEPTH TO PUMP: 35

14) WELL TEST:

JETTED

YIELD: 11 GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY:

TYPE OF WATER: GOOD

DEPTH OF STRATA: 15 - 43

NO STRATA OF UNDESIRABLE WATER PENETRATED

CHEMICAL ANALYSIS MADE

0 GRAINS OF HARDNESS

780 T.D.S.

COMPANY NAME: VIRDELL DRILLING INC.

WATER WELL DRILLER'S LICENSE NO.: 1900 (4071) WPKL

FOR TWC USE ONLY

ADDRESS: 111 E. GRAYSON ST.

CITY: LLANO

STATE: TX ZIP CODE: 78643

WELL NO. _____

LOCATED ON MAP _____

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 15 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed)

Lynn Hoy
(LICENSED WATER WELL DRILLER)

(signed)

(REGISTERED DRILLER TRAINEE)



111 E. GRAYSON ST.
LLANO, TEXAS 78643
(915) 247-4249

SOLD TO:

NED WOODALL
P.O. BOX 7807
REYNOLDS STATION
WINSTON SALEM, NC 27109-7807

DATE: 08/08/01
INVOICE NO: 26887
TERMS: NET 30

CUSTOMER NO. 04989

pd. 8/14
CH# 2329

INVOICE

QUANTITY	DESCRIPTION	UNIT PRICE	AMOUNT
	LLANO CO.; FLAG CREEK OAKS, LOT #15 =====		
	*****WELL TEST*****		
	WELL DEPTH..... 44'		
	STATIC WATER LEVEL.....14.5'		
	PUMP SETTING..... 35'		
	GALLONS PER MINUTE..... 8		
	(WHICH WAS THE CAPACITY OF THE PUMP IN THE WELL)		
1	BACTERIAL SAMPLE TO UGRA LAB	41.50T	41.50
1	SERVICE CALL	150.00T	150.00
** THANK YOU **			
PLEASE SEND TOTAL DUE TO THE LLANO OFFICE			
SUB-TOTAL			191.50
SALES TAX			11.97
TOTAL			203.47

ALL ACCOUNTS
30 DAYS OLD ARE
CONSIDERED
PAST DUE. A
FINANCE CHARGE
OF 1-1/2%
PER MONTH
(18% ANNUAL)
WILL BE ADDED
TO ALL PAST DUE
ACCOUNTS.