


IONIA COUNTY HEALTH DEPARTMENT 175 E. ADAMS STREET, IONIA, MI 48846		VACANT LAND SOIL EVALUATION	ENVIRONMENTAL HEALTH DIV 616-527-5341	
Requester's Name: <u>MARK SHELTON</u>		Date: <u>10/17/13</u>		Acres: <u>100</u>
Road: <u>3550 DIVINE HWY.</u>				
Twp: <u>PORTLAND</u>	Sec: <u>3</u>	Boring 1:	Boring 2:	
Approved for permit ☐		<u>0-9" SILT LOAM TOPSOIL</u>	<u>0-6" SANDY LOAM TOPSOIL</u>	
boring 1 ☒ 2 ☒ 3 ☐ 4 ☐		<u>9-60" SILT LOAM</u>	<u>6-23" COARSE SANDY LOAM & GRAVEL</u>	
Denied permit ☐			<u>23-53" FINE SAND & GRAVEL</u>	
Approved for alternative ☐				
(Application expires in 12 months)		Water table depth: <u>ABSENT</u>	Water table depth: <u>ABSENT</u>	
		Boring 3:	Boring 4:	
		Water table depth:	Water table depth:	

THIS IS **NOT** A PERMIT



COMMENTS:

DRAWING NOT TO SCALE. SOIL EVALUATION IS FOR A SLIT OF
40 ACRES OFF OF A 100 ACRE PARCEL. BORING 2 IS PREFERABLE
FOR A CONVENTIONAL SYSTEM.

BOWEN

Sanitarian