NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPERECEIVED

STATE OF OREGON

(Please type or print) (Do not write above this kneek R RESOURCES DEFT.

NOV 151977 State Well No. 4

17	SALEM. ORECON	<u> </u>	
(1) OWNER:	(10) LOCATION OF WELL:		
Name Carl Rajnus	County klamath Driller's well n	umber	
Address Rt 2 Box 784 Klamath Falls, Oregon	N.W. 145 E. 14 Section 29 T. 40S	r. 12E	W.M.
97601	Bearing and distance from section or subdivisi	ion corner	
(2) TYPE OF WORK (check):			
New Well 🖔 Deepening 🗌 Reconditioning 🗍 Abandon 🗌			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	vell.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 165 ft.		
Rotary Driven Democratic Democratical Democr	Static level 756 ft. below land	surface. Date	11/11/7
Cable K Jetted □ Domestic □ Industrial □ Manicipal □ Dug □ Bored □ Irrigation ▼ Test Well □ Other □	1,0	re inch. Date	<u> </u>
CASING INSTALLED: Threaded Welded 12 14 15 15 16 17 17 18 19 18 19 18 19 19 19	(12) WELL LOG: Diameter of well below casing 10 Depth drilled 710 ft. Depth of completed well 710 ft.		
"Diam. from			
" Diam, from ft. to ft. Gage	Formation: Describe color, texture, grain size and show thickness and nature of each stratu		
DEDWOD A TYONG	with at least one entry for each change of forms position of Static Water Level and indicate pri		
PERFORATIONS: Perforated? Yes X No.		T	swL
Type of perforator used	MATERIAL	From To	SWD
Size of perforations in. by in.	top soil	0 2	
perforations from ft. to ft.	brown lava boulders&clay	2 40	
perforations from ft. to ft.	brown cong.	40 52	
perforations from ft. to ft.	brown sandstone	52 74	
(7) SCREENS: Well screen installed? Yes X No	yellow clay	74 92	
Manufacturer's Name	gray basalt	92 134	
Type Model No	brown cong.	134 287	156
Diam. Slot size Set from ft. to ft.	gray shale	287 405	**
Diam. Slot size Set from ft. to ft.	gray lava	405 472	11
Diant. Stor size See 11011	brown lava	472494	11
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	gray & brown lava	668 690	11
	gray shale	690 692	11
Was a pump test made? Wes I No If yes, by whom? Vield: 638 gal./min. with 132 ft. drawdown after 4 hrs.	brown & gray cong.	692 710	**
	OTOMIT & STAY COLIS.	1036 110	
" "			
n n n	-		
Bailer test gal./min. with ft. drawdown after hrs.			
Artesian flow g.p.m. perature of water 62 Depth artesian flow encountered ft.	Work started 5730 1977 Comple	1 1 /2 2	1977
sperature of water OZ Depth accession now encountered	1 — L -		1977
(9) CONSTRUCTION:	Date well drilling machine moved our of well	<u> </u>	19 ((
Well seal—Material usedcement	Drilling Machine Operator's Certification		
Well sealed from land surface to18	This well was constructed under my direct supervision. Materials used and information reported above are true to my		
Diameter of well bore to bottom of sealin.	best knowledge and belief.	X -	
Diameter of well bore below seal in.	[Signed]		
Number of sacks of cement used in well seal9	Drilling Machine Operator's License No. 118		
How was cement grout placed?pored in from top	Drilling Machine Operator's License No.		***************************************
	Water Well Contractor's Certification:		
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was a drive shoe used? Yes No Plugs Size: location ft.			
Did any strata contain unusable water? Tyes X No	Name John A. Van Meter (Person, firm or corporation)	(Type or p	rint)
Type of water? depth of strata	Address Box 204 Malin Ope	- A	
Method of sealing strata off	A LITTERY	1.4	
Was well gravel packed? Yes No Size of gravel:	[Signed]	tractor)	
Gravel placed fromft. toft.	Contractor License No. 170 Date	11/12	, 1977
			<u> </u>