

76-6-313-12

SEWAGE DISPOSAL SYSTEM PERMIT Number 87-84

This Permit Expires One Year From Date Issued

This permit is issued by the Union County Health Department to construct and install the work hereby described. The construction shall be made in compliance with the N.C. Division of Health Services Laws and Rules for Sewage Disposal Treatment and Disposal Systems and Union County Health Department Rules and Regulations.

NAME/LOCATION DEPENDENCE ESTATE 3 LOT 287 NEWTON RD. CHARTER

OWNER ONE CHARTER ADDRESS 2501 F. INDEPENDENCE BLVD. CHARTER

INSTALLATION FOR HOUSE Apt. House

LOT SIZE 5.03 A. Number of living units 1 Private well Approved 2 1/2" x 10' Garbage grinder yes no

Soil character to depth of 3 feet sand clay sandy loam silt loam Other

Soil performance criteria: (Suitable, Provisionally suitable, Unsuitable): Unsuitable Permeability 3.0 Slope/grade 3

Conductive soil layers 3 Water table 3 Soil depth 5' Area 3

Plot plan, showing size of lot, location of system in relation to wells, buildings, etc. on reverse side.

NO INSTALLATION: (No individual sewage disposal system permitted within 200 feet of public sewer.)

Septic tank ✓ Size 1000 GA. Capacity 1000 GA. Number of compartments 2

Pump tank ✓ Size 10' Capacity 10' Pump flow, g/p.m. 10 Tot. dyn. head 10'

Distance to nearest well 10' Waterline 10' Foundation 10' Property line 10'

Sanitization line ✓ No. lines 5 Trench width 30" Sq. ft. 1000 D-box ✓ Filter mat./depth 10"

Distance to nearest well 10' Waterline 10' Foundation 10' Property line 10'

Rebuild/replace previous sewage disposal system permit number 10' Dated 5/10/87

Capacity tank 10' Size 10' Capacity 10' Number of compartments 10'

Sanitization line 10' No. lines 10' Trench width 10' Sq. ft. 10' D-box 10' Filter mat./depth 10'

Pump tank 10' Capacity 10' Pump flow 10' Total dynamic head 10'

I hereby certify that this application has been prepared and the work will be done in accordance with the Union County Ordinances, State Laws, Rules and Regulations of the Union County Health Department.

Notice: The issuance of this permit does not relieve the property owner of this responsibility for checking his proposed development with applicable zoning regulations.

Signed James L. Brown agent

Permit prepared by James L. Brown Date prepared: 5/10/87

Final inspection by: James L. Brown Date of inspection: 5/16/88

Contractor: James L. Brown Comments: James L. Brown

UNION COUNTY HEALTH DEPARTMENT

