

TARRANT COUNTY WATER CONTROL AND IMPROVEMENT
DISTRICT NUMBER ONE

(authorized by)

TEXAS WATER CODE SS5.103 and 5.105

Subchapter N
Richland Chambers Reservoir SS 285.401 - 285.414

PERMIT FOR A PRIVATE SEWAGE FACILITY

NAME: J.R. COKER DATE: 6/10/96
LOT NO: -22- BLOCK: --- SEC.: ---
ADDITION: HIDE-AWAY HARBOR COUNTY: NAVAROO
LOT STREET ADDRESS: N/A
WATER SUPPLIED BY: M.E.N. NUMBER OF BEDROOMS: 2
SIZE OF LOT: 21,780 SQ. FT. LIVING AREA: 1,443 SQ. FT.

PERCOLATION RESULTS

PERSON/FIRM PERFORMING TEST: T.C.W.C. & I.D. #1
AVERAGE PERCOLATION RATE: -130- TYPE OF SYSTEM: EVAPOTRANSPIRATION BEDS

MINIMUM REQUIREMENTS

SEPTIC TANK MINIMUM LIQUID CAPACITY IN GALLONS: 750
TOTAL EVAPOTRANSPIRATION BED AREA: 1,408 SQ. FT. (MINIMUM TWO BEDS REQUIRED)
TOTAL ABSORPTION FIELD AREA: N/A SQ. FT. (DITCH SYSTEM ONLY)
CONVENTIONAL DITCH AS FOLLOWS:

24" WIDE DITCH N/A FEET LONG
30" WIDE DITCH N/A FEET LONG
36" WIDE DITCH N/A FEET LONG
LEACHING CHAMBER SYSTEM N/A FEET LONG

SPECIAL INSTRUCTIONS

THE ABOVE PERMITTED SYSTEM SHALL BE INSTALLED ACCORDING TO THE "TEXAS DEPARTMENT OF HEALTH CONSTRUCTION STANDARDS FOR ON-SITE SEPTIC SYSTEMS".

NOTE: SEE DRAWING FOR PERCOLATION TEST AREA

NOTE: AN INSPECTION MUST BE PERFORMED BY TARRANT COUNTY WATER CONTROL AND IMPROVEMENT DISTRICT NUMBER ONE PRIOR TO COVERING ANY PART OF THE SYSTEM. AN APPOINTMENT CAN BE MADE BY CALLING (903) 389-3928 BETWEEN 7:30 AND 8:30 A.M.

TARRANT COUNTY WATER CONTROL AND
IMPROVEMENT DISTRICT NUMBER ONE

James H. Bailey
AUTHORIZED REPRESENTATIVE

NOTE: THIS PERMIT IS VALID FOR ONE YEAR FROM DATE ISSUED.

