

To: Borrer, William P. Address: HC 33, Box 947, Petersburg, WV 26847

Installer: Sites, Lysle R. - HC 33, Box 984, Petersburg, WV 26847

You are hereby issued a permit to construct
a small sewage disposal system consisting of a tank and absorption field
and located at Rt. 42 to Maysville - left @ Cook's Store to Twin Oaks Subdivision,
Section B, Lot 13

This small sewage disposal system shall meet the following specifications:

1. Septic Tank
 - a. Shall be made of precast concrete and not less than 1,000 gallon capacity.
2. Soil-Absorption System
 - a. Shall consist of 2 distribution lines 4" in diameter.
 - b. Each distribution line shall be 100 100 feet in length
 - c. Each trench shall be 36 inch width with ZERO slope on trench bottom and ZERO slope on each distribution line.
 - d. No trench shall be more than 18-24 inches deep.
 - e. Total soil-absorption area in trench bottoms shall be 600 sq. ft.
 - f. Filter material shall be gravel and not greater than 1/2 - 2 1/2 inches in diameter.
 - g. Filter material under each line shall be not less than 6 inches deep and not less than 2 inches over each distribution line.
 - h. Filter material shall be covered with paper prior to backfilling.
 - i. Trenches shall be backfilled at least 6" above ground surface to provide for settling of backfill.
3. Other Small Sewage or Excreta Disposal Systems (Name the type system to be used, then use back of sheet to describe the details of the system.)
4. Special Requirements
 - a. Small sewage and excreta disposal systems shall be located at least 10 ft. from any property line and a minimum of 20 ft. from any stream or roadside cut.
 - b. Septic tanks shall be located at least 10 ft. and excreta disposal systems a minimum of 20 ft. from building foundation.
 - c. Septic tanks shall be located a minimum of 50 ft. and soil-absorption systems and excreta disposal systems a minimum of 100 ft. from any ground water supply or cistern.
5. This permit is not transferable and automatically expires 12 months after date of issue.
6. The applicant or his agent must notify this department, phone 257-4922 at least 48 hours before the system is ready for inspection.
7. All small sewage and excreta disposal systems must be inspected and approved prior to being covered with earth or otherwise put into service. Any applicable system or part thereof covered before being inspected shall be uncovered at the direction of the SANITARIAN.
8. This permit is NULL AND VOID when official inspection reveals conditions are different than those stipulated in this permit or if facts later become known that a health hazard would result by the installation of this system.

08-29-96 RGL/ag

Date of Issue
GRANT COUNTY HEALTH DEPARTMENT
P. O. Box 608
Petersburg, WV 26847

Health Department

*Sent DEP Application...

(Use reverse side of page for sketch of system)

Robert G. Livingston
Name

Robert G. Livingston, Sanitarian
Title

SS-177
Revised 1-71

WEST VIRGINIA
SEPTIC TANK INSPECTION FORM

Grant County Health Department Installation Permit No. SS1296067

Name of Owner Borrer, William P.

Address HC 33, Box 947, Petersburg, WV 26847

Property Address Rt. 42 to Maysville - left @ Cook's Store to Twin Oaks Subdivision,
Section B, Lot 13.

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served RESIDENCE No. Water Closets 1

Lot Size 2.09 AC sq. ft. Area suitable for sewage disposal installation 7,000 ± sq. ft

Source of Water Supply PUBLIC No. Lavatories 1

No. Bedrooms 3 No. Showers or Tubs 1 No. Baths 1

No. Garbage Grinders 1 No. Automatic Washers 1

SEPTIC TANK

Material PRECAST CONCRETE Length 8 x Width 5 1/2 x Depth 4 1/2 = 105.0 cubic feet

Liquid Depth ft. Liquid Capacity 1000 500 IN gal.

Distance to: Dwelling 47' Water Supply E 57 50 ±' Nearest Property Line E 37 100 ±'

SOIL ABSORPTION SYSTEM

Type Drain Line Material PLASTIC Trench Width 36 Inches

Trench Depth 24 Inches Total Absorption area in Trench Bottom 600 sq. ft.

Diameter of Drain Line 4 Inches Type Filter Media GRAVEL

No. of Drain Lines 2 Depth Filter Media Under Drain Line 6 Inches

Length of Each Line 100, 100, , ft. Depth Filter Media Over Drain Line 2 in

Distance of Disposal Field to: (a) Dwelling 65'

(b) Water Supply E 37 100 ±' (c) Nearest Property Line E 37 100 ±'

An inspection of the septic tank system described herein disclosed that said system (MEETS) ~~DOES NOT MEET~~ the minimum standards established by the West Virginia State Department of Health.

10/4/96
Date

Robert Livingston
Sanitarian Robert G. Livingston

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

