

**Kathy Beckham**

**From:** "Virdell Drilling" <virdelldrilling@verizon.net>  
**To:** "Kathy Beckham" <kbeckham@remax-llano-tx.com>  
**Sent:** Tuesday, April 30, 2013 11:11 AM  
**Subject:** for Gina: Emailing: Well Report Tracking #74192.htm

## STATE OF TEXAS WELL REPORT for Tracking #74192

Owner:	<b>Peter Malin Six Peaks LLC</b>	Owner Well #:	<b>No Data</b>
Address:	<b>5925 Forest Lane, Ste. 505 Dallas , TX 75230</b>	Grid #:	<b>57-26-2</b>
Well Location:	<b>1 mi. W from CR 113 on CR 112; .2 mi. N on tract (Center Tract Well) TX</b>	Latitude:	<b>30° 36' 27" N</b>
Well County:	<b>Llano</b>	Longitude:	<b>098° 48' 47" W</b>
Elevation:	<b>No Data</b>	GPS Brand Used:	<b>Garmin III</b>
Type of Work:	<b>New Well</b>	Proposed Use:	<b>Domestic</b>

Drilling Date:      Started: **1/12/2006**  
                          Completed: **1/12/2006**

Diameter of Hole:      Diameter: **9 in From Surface To 36 ft**  
                          Diameter: **6.75 in From 36 ft To 37 ft**  
                          Diameter: **6 in From 37 ft To 60 ft**

Drilling Method: **Air Hammer**

Borehole Completion:      Gravel Packed From: **20 ft to 37 ft**  
                          Gravel Pack Size: **4A**

Annular Seal Data:      1st Interval: **From 0 ft to 10 ft with 1 Cement (#sacks and material)**  
                          2nd Interval: **From 10 ft to 20 ft with 3 Bentonite (#sacks and material)**  
                          3rd Interval: **No Data**  
                          Method Used: **Grout**  
                          Cemented By: **Lynn Hoy**  
                          Distance to Septic Field or other Concentrated Contamination: **No**

**Data**Distance to Property Line: **50+ ft**Method of Verification: **measure**Approved by Variance: **No Data**

Surface  
Completion: **Surface Sleeve Installed**

---

Water Level: Static level: **12 ft. below land surface on 1/12/2006**  
Artesian flow: **No Data**

Packers: **No Data**

Plugging Info: Casing or Cement/Bentonite left in well: **No Data**

Type Of Pump: **Submersible**  
Depth to pump bowl: **50 ft**

Well Tests: **Jetted**  
Yield: **30 GPM with (No Data) ft drawdown after (No Data) hours**

---

Water Quality: Type of Water: **good (430 ppmTDS)**  
Depth of Strata: **20 - 36 ft.**  
Chemical Analysis Made: **No**  
Did the driller knowingly penetrate any strata which contained undesirable constituents: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the log(s) being returned for completion and resubmittal.

Company Information: **Virdell Drilling Inc.**  
**111 E. Grayson St.**  
**Llano , TX 78643**

Driller License Number: **4071**

---

Licensed Well Driller Signature: **Lynn Hoy**

Registered Driller Apprentice Signature: **No Data**

Apprentice            **No Data**  
 Registration  
 Number:  
 Comments:           **No Data**

---

**IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED  
 CONCERNING CONFIDENTIALITY**

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #74192) on your written request.

**Texas Department of Licensing & Regulation  
 P.O. Box 12157  
 Austin, TX 78711  
 (512) 463-7880**

**DESC. & COLOR OF FORMATION  
 MATERIAL**

From (ft)	To (ft)	Description
<b>0 - 1</b>		<b>Topsoil</b>
<b>1 - 20</b>		<b>Granite Gravel &amp; Clay</b>
<b>20 - 36</b>		<b>Granite Gravel</b>
<b>36 - 60</b>		<b>Red Granite</b>

**CASING, BLANK PIPE & WELL  
 SCREEN DATA**

Dia.	New/Used	Type	Setting
	From/To		
<b>6"</b>	<b>N</b>	<b>PVC +2 - 32</b>	<b>sch 40</b>
<b>6"</b>	<b>N</b>	<b>PVC, Custom Slott</b>	<b>32 - 37 sch 40</b>