

Revised 1-71

WEST VIRGINIA SEPTIC TANK INSPECTION FORM

Hampshire County Health Department Installation Permit No. ST-14-79-16

Name of Owner EDWARDS HOWARD

Address 1506 PATTISON Rd., BALTIMORE, MD. 21221

Property Address VALLEY VIEW SUB-DIVISION, TRACT No. 2, Right 1/4 MI. AT McBAIDE'S STOR.

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served NEW HOUSE No. Water Closets 1

Lot Size 7.29 ACRES sq. ft. Area suitable for sewage disposal installation 15,000 sq. ft

Source of Water Supply DRILLED WELL No. Lavatories 1

No. Bedrooms 2 No. Showers or Tubs 1 No. Baths 1

No. Garbage Grinders 0 No. Automatic Washers 1

SEPTIC TANK

Material CONCRETE Length x Width x Depth = cubic feet

Liquid Depth ft. Liquid Capacity 1,000 gal.

Distance to: Dwelling 24' Water Supply 90' Nearest Property Line 200'+

SOIL ABSORPTION SYSTEM

Type Drain Line Material PLASTIC Trench Width 24 Inches

Trench Depth 30 Inches Total Absorption area in Trench Bottom 480 sq. ft.

Diameter of Drain Line 4 Inches Type Filter Media GRAVEL

No. of Drain Lines 3 Depth Filter Media Under Drain Line 6 Inches

Length of Each Line 80', 80', 80', ft. Depth Filter Media Over Drain Line 2 in

Distance of Disposal Field to: (a) Dwelling 60'

(b) Water Supply 110' (c) Nearest Property Line 200'+

An inspection of the septic tank system described herein disclosed that said system (MEETS, ~~DOES NOT MEET~~) the minimum standards established by the West Virginia State Department of Health.

MARCH 20, 1979 Date

Sanitarian

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

