

required items will result in the log(s) being returned for completion and resubmittal.

Company Information: **Virdell Drilling Inc.**
111 E. Grayson St.
Llano , TX 78643

Driller License Number: **1900**

Licensed Well Driller Signature: **Taylor Virdell Jr.**

Registered Driller Apprentice Signature: **James Caleb Virdell**

Apprentice Registration Number: **3254**

Comments: **No Data**

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #106384) on your written request.

Texas Department of Licensing & Regulation
P.O. Box 12157
Austin, TX 78711
(512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

From (ft)	To (ft)	Description
0	1	Topsoil
1	11	Brown Clay
11	178	Red Clay & Limestone w/Sand Streaks

CASING, BLANK PIPE & WELL SCREEN DATA

Dia.	New/Used	Type	Setting From/To
5"	N	PVC +2	158 SDR 17
5"	N	PVC, Custom Slott	158 - 178 SDR 17

STATE OF TEXAS WELL REPORT for Tracking #106384

Owner:	Angela Heath	Owner Well #:	No Data
Address:	434 Southwoods Dr. Fredericksburg, TX 78624	Grid #:	57-41-9
Well Location:	The Vineyards, Lot #11 TX	Latitude:	30° 16' 36" N
Well County:	Gillespie	Longitude:	098° 53' 41" W
Elevation:	No Data	GPS Brand Used:	Garmin III
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Date: Started: 3/9/2007
Completed: 3/9/2007

Diameter of Hole: Diameter: 8.75 in From Surface To 178 ft

Drilling Method: Air Rotary

Borehole Completion: Gravel Packed From: 50 ft to 178 ft
Gravel Pack Size: 4A

Annular Seal Data: 1st Interval: From 1 ft to 3 ft with 1 Cement (#sacks and material)
2nd Interval: From 3 ft to 50 ft with 11 Bentonite (#sacks and material)
3rd Interval: No Data
Method Used: Grout
Cemented By: Taylor Virdell Jr.
Distance to Septic Field or other Concentrated Contamination: No Data
Distance to Property Line: 78' ft
Method of Verification: No Data
Approved by Variance: No Data

Surface Completion: Pitless Adapter Used

Water Level: Static level: 73 ft. below land surface on 3/9/2007
Artesian flow: No Data

Packers: No Data

Plugging Info: Casing or Cement/Bentonite left in well: No Data

Type Of Pump: Submersible
Depth to pump bowl: 160 ft

Well Tests: Jetted
Yield: 25 GPM with (No Data) ft drawdown after (No Data) hours

Water Quality: Type of Water: good (430 ppmTDS)
Depth of Strata: 90-97, 140-175 ft.
Chemical Analysis Made: No
Did the driller knowingly penetrate any strata which contained undesirable constituents: No

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the

Regulated by The Texas Department of Licensing and Regulation, P.O. Box 12157, Austin Texas 78711, 1-800-803-9202, 512-463-7880