

ATTENTION OWNER: Confidentiality  
Privilege Notice on Reverse SideStat of Texas  
WELL REPORTTexas Water Well Drillers Advisory Council  
P.O. Box 13087  
Austin, TX 78711-3087  
512-239-0530

1) OWNER MR. FRANK BECTRAN ADDRESS Box 249 Evant Tx 76525  
(Name) (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL: County CORNELL Rt. 1 Box 249 Evant Tx 76525 GRID # 41-39-3  
(Street, RFD or other) (City) (State) (Zip)

3) TYPE OF WORK (Check):  
☒ New Well ☐ Deepening  
☐ Reconditioning ☐ Plugging

4) PROPOSED USE (Check): ☐ Monitor ☐ Environmental Soil Boring ☒ Domestic  
☐ Industrial ☐ Irrigation ☐ Injection ☐ Public Supply ☐ De-watering ☐ Testwell  
If Public Supply well, were plans submitted to the TNRCC? ☐ Yes ☐ No

5)

## 6) WELL LOG:

Date Drilling: 9/6 19 95  
Started 8/9 19 95  
Completed 8/9 19 95

## DIAMETER OF HOLE

Dia. (in.)	From (ft.)	To (ft.)
<u>6 1/2</u>	Surface	<u>510</u>

7) DRILLING METHOD (Check): ☐ Driven  
☒ Air Rotary ☐ Mud Rotary ☐ Bored  
☐ Air Hammer ☐ Cable Tool ☐ Jetted  
☐ Other \_\_\_\_\_

X

↑

From (ft.) To (ft.) Description and color of formation material

0 - 2	SURFACE
2 - 18	CLAY
18 - 32	SHALE
32 - 45	SANDY SHALE
45 - 340	SHALE
340 - 425	BROWN LIME ROCK
425 - 435	RED BED
435 - 455	BROWN LIME ROCK
455 - 475	PORUS LIME ROCK
475 - 495	BROWN LIME ROCK
495 - 510	YELLOW BED

8) Borehole Completion (Check): ☐ Open Hole ☐ Straight Wall  
☐ Underreamed ☒ Gravel Packed ☐ Other \_\_\_\_\_  
If Gravel Packed give interval ... from 310 ft. to 510 ft.

## CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
4"	N	SCH #40 PUC	0	510	

## 9) CEMENTING DATA [Rule 338.44(1)]

Cemented from 0 ft. to 18 ft. No. of sacks used 5  
300 ft. to 310 ft. No. of sacks used 5  
Method used WET CEMENT  
Cemented by Edon Jenkins  
Distance to septic system field lines or other concentrated contamination 250 ft.  
Method of verification of above distance TAPE

## 13) TYPE PUMP:

☐ Turbine ☐ Jet ☒ Submersible ☐ Cylinder  
☐ Other \_\_\_\_\_

Depth to pump bowls, cylinder, jet, etc., 460 ft.

## 14) WELL TESTS:

Type test: ☐ Pump ☐ Bailer ☒ Jetted ☐ Estimated  
Yield: 10 gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

## 15) WATER QUALITY:

Did you knowingly penetrate any strata which contained undesirable constituents?

☐ Yes ☒ No If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? GOOD Depth of strata 455-475  
Was a chemical analysis made? ☐ Yes ☒ No

## 10) SURFACE COMPLETION

☒ Specified Surface Slab Installed [Rule 338.44(2)(A)]  
☐ Specified Steel Sleeve Installed [Rule 338.44(3)(A)]  
☐ Pitless Adapter Used [Rule 338.44(3)(b)]  
☐ Approved Alternative Procedure Used [Rule 338.71]

## 11) WATER LEVEL:

Static level 320 ft. below land surface Date 9/9/95  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

## 12) PACKERS:

Type Depth

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Edon Jenkins Drilling WELL DRILLER'S LICENSE NO. 2782 W  
(Type or print)

ADDRESS P.O. Box 129 Evant Tx 76525  
(Street or RFD) (City) (State) (Zip)

(Signed) Edon Jenkins (Signed) \_\_\_\_\_  
(Licensed Well Driller) (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.