

end original copy by
certified mail to the
Texas Department of Water Resources
P. O. Box 13087
Austin, Texas 78711

State of Texas
WATER WELL REPORT

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

For TDWR use only

Well No. _____

Located on map _____

Received _____

1) OWNER Oscar Lantz
(Name)

Address 3021 Wintersham (Street or RFD) Frederickburg (City) Texas (State) 78624 (Zip)

2) LOCATION OF WELL:

County Frederickburg

in Town
(N.E., S.W., etc.)

direction from Frederickburg
(Town)

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Section Texas County General Highway Map and attach the map to this form.

☐ Legal description:

Section No. _____ Block No. _____ Township _____

Abstract No. _____ Survey Name _____

Distance and direction from two intersecting section or survey lines

98°52' Longitude 30°17' Latitude
☒ See attached map. # 1168

3) TYPE OF WORK (Check):

☒ New Well ☐ Deepening
☐ Reconditioning ☐ Plugging

4) PROPOSED USE (Check):

☒ Domestic ☐ Industrial ☐ Public Supply
☐ Irrigation ☐ Test Well ☐ Other _____

5) DRILLING METHOD (Check):

☐ Mud Rotary ☐ Air Hammer ☐ Driven ☐ Bored
☐ Air Rotary ☒ Cable Tool ☐ Jetted ☐ Other _____

6) WELL LOG:

DIAMETER OF HOLE

Dia. (in.) From (ft.) To (ft.)

77/8 Surface 90

Date drilled Dec. 23, 1980

7) BOREHOLE COMPLETION:

☐ Open Hole ☐ Straight Wall ☐ Underreamed
☒ Gravel Packed ☐ Other _____

If Gravel Packed give interval ... from _____ ft. to _____ ft.

From (ft.) To (ft.) Description and color of formation material

0 - 2 Sandy top soil
2 - 32 Red clay
32 - 40 Brown sand (dappled water)
40 - 52 Red clay & sand (water)
52 - 78 Red clay
78 - 84 Red clay & sand (water)
84 - 90 Red clay

Dia. (in.) New or Used Steel, Plastic, etc. Perf., Screened, etc. Screen Mfg., if commercial

5 N #160 PVC
Reamed
to 70
80 to 90

Setting (ft.) Gage Casing Screen

From To
+1 90

HN

CEMENTING DATA

Cemented from _____ ft. to _____ ft.

Method used _____

Cemented by _____
(Company or Individual)

9) WATER LEVEL:

Static level 21 ft. below land surface Date 12-23-80

Artesian flow _____ gpm. Date _____

10) PACKERS:

Type Depth

11) TYPE PUMP:

☐ Turbine ☐ Jet ☐ Submersible ☐ Cylinder
☐ Other _____

Depth to pump bowls, cylinder, jet, etc. _____ ft.

13) WATER QUALITY:

Did you knowingly penetrate any strata which contained undesirable water? ☐ Yes ☐ No

If yes, submit "REPORT OF UNDESIRABLE WATER"

Type of water? _____ Depth of strata 52' - 478'

Was a chemical analysis made? ☐ Yes ☐ No

12) WELL TESTS:

☐ Type Test ☐ Pump ☒ Sailer ☐ Jetted ☒ Estimated
Yield: 2.5 gpm with _____ ft. drawdown after _____ hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME Eldon Ray Feller Water Well Drillers Registration No. 1297

ADDRESS 1107 E. Main Frederickburg Texas 78624
(Street or RFD) (City) (State) (Zip)

1d) Eldon Ray Feller Feller water well drilling
(Water Well Driller) (Company Name)

attach electric log, chemical analysis, and other pertinent information, if available.

2 (Rev. 1-12-79)

WELL OWNER'S COPY