## WATER WELL REPORT STATE OF OREGON

## RECEIVED

OCT 1 2.1984

12UAM 1189

15.7

tate Well No. 355/7E-7.bd

State Permit No.

WATER RESOURCES DEPT

(1) OWNER:	(10) LOCATION OF WELL:
Name Margaret Johnson	County Klamath Driller's well number
Address St. Rt., Box 90A	S. E. 4 N. W. 4 Section 7 T. 35S R. 7E W.M.
City Chiloquin, State OR 97624	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location: Star Rt. 90A
	Chiloquin, OR 97624
New Well Deepening □ Reconditioning □ Abandon □	(11) WATER LEVEL: Completed well.
If abandonment, describe material and procedure in Item 12.	Depth at which water was first found 17 ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 9 ft. below land surface. Date 10/9/8
Rotary Air   Driven   Domestic   Industrial   Municipal	Artesian pressure lbs. per square inch. Date
Rotary Mud	(12) WELL LOG: Diameter of well below casing
	Depth drilled  Diameter of well below casing
(5) CASING INSTALLED: Steel CK Plastic Character Welded Xiv 250	Formation: Describe color, texture, grain size and structure of materials; and show
5/8"Diam from +1 ft. to 46 ft. Gauge -250	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
ft. Gauge	Sandy top soil 0 2
	Coarse sand and brn clay 2 4
(6) PERFORATIONS: Perforated? ▼ Yes □ No Type of perforator used factory	cemented pea gravel & sand 4 16
170	fine brn sand & clay 16 23
Size of perforations 1/0 in. by 4 in.  6 per ft. perforations from 26 ft. to 46 ft.	gray clay & coarse sand 23 27
	coarse sand pes gravel 27 42
perforations from	coarse sand-black 42 46
perforations from	
(7) SCREENS: Well screen installed?   Yes You	
Manufacturer's Name	
Type	
Diam. Slot Size Set from It. to It.  Diam. Slot Size Set from ft. to It.	
Drawdown is amount water level is lewond	
(8) WELL TESTS:  below static level	
Was a pump test made? □ Yes □ Yes □ Yes, by whom?	
d: gal/min. with ft. drawdown after hrs.	
И и и	
Air test gal./min. with drill stem at ft. hrs.	4,
Bailer test 10 gal./min. with 5 ft. drawdown after 1 hrs.	
esian flow g.p.m.	
perature of water 56 Depth artesian flow encountered ft.	Work started 10/5/84 19 Completed 10/9/84 19
(9) CONSTRUCTION: Special standards: Yes □ No 🗓	Date well drilling machine moved off of well $10/9/84$ 19
Well sealed from land surface to 25 st	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal1Qin.	and information reported above are true to my best knowledge and belief.
Diameter of well bore below sealin.	[Signed] OLUM X) JULY Date 1.0/9/., 19.84.
Number of sacks of cement used in well seal sacks How was cement grout placed? Srout pipe	Drilling Machine Operator's License No.
How was cement grout placed?	Water Well Contractor's Certification:
The state of the s	This well was drilled under my jurisdiction and this report is true to
Was pump installed?NQTypeHPDepthft.	the best of my knowledge and belief.
Was a drive shoe used? MY Yes □ No Plugs Size: location ft.	Name (Type or print)
Did any strata contain unusable water? □ Yes □ No	Address 3/11 BOAWMAN K, 54 5 0V
Type of Water? surface depth of strata 23	
Method of sealing strata off cement	[Signed] ( ) (Water Well Contractor)
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	Contractor's License No. 1228. Date 10.19.
Gravel placed fromft. toft.	