



Hampshire County Health Department

HC 71, Box 9

Augusta, WV 26704

Nursing: (304) 496-9640 Environmental: (304) 496-9641

Fax: (304) 496-9650

Hampshire County Planning Commission
PO Box 883
Romney, WV 26757

Dear Sirs:

This office has reviewed an application for Charles Brown to approve lot 8 in Eagle Bay Properties, and further referenced as Tax District Bloomery, Tax Map 19A, Parcel 227, Deed book 422, Page 320. This lot contains 21.624 acres. All lots require a percolation test and a sewage disposal area of 10,000 square feet where no development or structures other than the septic system shall be permitted. This lot is to be developed with an individual well and septic system to serve a single family dwelling. GPS North 39 26 48.8 West 78 25 00.8

Percolation test results are within limits as set forth by West Virginia CRS 16-1. Six foot soil observation holes indicate no restrictions due to water table or shallow bedrock within the designated sewage disposal area except as noted on the Health Department subdivision application.

The application dated 5/13/2013, is hereby approved by the Hampshire County Health Department. Any changes or revisions to the lot, or subsequent plats, may make this approval null and void.

This approval is not permit for individual water systems or individual sewer systems. Applications for permits must be made separately to the Hampshire County Health Department.

Sincerely,

A handwritten signature in black ink, appearing to read "Derrick Haggerty", is written over a horizontal line.

Derrick Haggerty
Sanitarian

CC: Charles Brown