

Oct 06 17 06:56p

Johnny or Karen Holton

806-447-9921

p.3



Aldebaran, Inc.
CATHODIC PROTECTION
SERVICES

PO Box 1301
Pampa, TX 79066

806-886-8713

Steve Osborn

ANNUAL CATHODIC PROTECTION REPORT

Tested: 7-07-14

Tested by: Steve Osborn

Facility: Gary's Lawnmower Shop

City: Childress

Address: Hwy 287

State: TX 79095

Rectifier: Brance-Krachy

Model: ES 20-10

Serial #: 987492

Hours: N/A

Volts 4.0 Amps: 1.9

Coarse: 1 Fine: 3

Tank#1 East	Tank#2	Tank#3	Tank#4 West
-1.016	-1.129	-1.218	-1.196
-1.103	-1.034	-1.194	-1.213
-.998	-1.182	-1.038	-1.264