



718 S. Michigan

Howell, MI 48843

(517) 548-2505

Fax (517) 548-3434

WATER ANALYSIS RESULTS**Report Results To:**

John Haack
7023 Munsell
Howell MI 48843

Completed by sampler:
Date Collected: 04/02/98
Time Collected: 6:55
Collected by: J. Haack
Sample Point: bathtub
Send Result: Client to pickup

Sample collection point:

7023 Munsell
Howell MI

97-0865
10SC0

Completed by Lab:
Date Received: 04/02/98
Date Released: 04/03/98
Sample Code: 04/02/98 1 B

TEST	RESULT	UNITS	DETECTION	MAXIMUM
			LIMIT	DESIREABLE LIMIT
Total Coliform	0	CFU/100 ml		MCL=0

Released by: James Nye

Laboratory #23 assigned by the Michigan Department of Environmental Quality for the microbiological and chemical analysis of drinking water.

ABBREVIATIONS:

MCL Maximum Contaminant Level-The maximum permissible level established by the USEPA and or MDPH for safe drinking water.
SMCL Secondary Maximum Contaminant Level-Suggested maximum level established by the USEPA for desireable water quality.
CFU/100 ml Colony Forming Units/100 milliliter sample volume.
mg/L Milligrams per liter umhos/cm Microhms per centimeter
"*" Denotes the MCL has been exceeded, safety cannot be assured.

Michigan Department of Environmental Quality

Drinking Water Laboratory - DWRP Division

3500 N. M.L. King Blvd. Lansing MI 48909

517/335-8184

Official Laboratory Report

Report To:

John Haack
524 Meadowview
Fowlerville MI 48836

Sample Number: C1998020435
Customer Number: 86689000

System Name/Owner: John Haack
Collection Address: 7023 Munsell, Howell 48843
Collected By: John Haack
Twp/Sec/Well #: 34/13/NEW
County: Iosco
Collector: Private Citizen
Sample Kit #: 32
Chlorination: None

WSSN / Pool ID:

Sampled: 03/03/1998 3:15:00PM
Received: 03/05/1998 02:58PM
Source: Single Family
Purpose: Repair/Construction/New Well
Water System: Untreated Private Well
Sample Point: WELL SPIGOT
Site Code: 97-0865NW

		Supplemental Information Related To Reported Result			
Test Result	Analyte Name	Tested	Health Limit MCL	Minimum Rpt.	Test Code
Not Detected	CHLORIDE (AUTOMATED)	03/09/1998		4 mg/L	CRA 19960701
0.2 mg/L	FLUORIDE (AUTOMATED)	03/09/1998	4.0 mg/L	0.1 mg/L	CRA 19960701
333 mg/L	HARDNESS AS CaCO3	03/09/1998		10 mg/L	CRA 19960701
0.1 mg/L	IRON (AUTOMATED)	03/09/1998		0.1 mg/L	CRA 19960701
Not Detected	NITRATE AS N (AUTOMATED)	03/09/1998	10 mg/L	0.4 mg/L	CRA 19960701
Not Detected	NITRITE AS N (AUTOMATED)	03/09/1998	1 mg/L	0.05 mg/L	CRA 19960701
8 mg/L	SODIUM (AUTOMATED)	03/09/1998		5 mg/L	CRA 19960701
53 mg/L	SULFATE (AUTOMATED)	03/09/1998		5 mg/L	CRA 19960701

Laboratory Comments and Result Notes: None