

Hampshire County Health Department On-Site Sewage Disposal System Inspection Form

Permit # **ST-14-07-269**

Name of Owner: Charles Bess Installer: Walter Fields
Address: PO Box 944, Keyser, WV 26726
Property Location: French's Neck West Lot 47 Lot Size: 5.7AC Acres
Type of Facility: Residence Facility is: ☒ New ☐ Existing
Design Loading in gpd/# Bedrooms: 2 Source of Water: Prop Well

SEWAGE TANK COMPONENT

Capacity in Gallons: 1000 Material: precast concrete Manufacturer: _____
Pump Chamber gal
Distances (in feet) of Tank to: Dwelling 80
Private ☐ Public ☐ Water Source: _____ Property Line: > 100'

ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Trenches () or Bed () Gravelless Pipe (), Diameter In.
Chamber Soil Absorption Trenches (x) or Bed ()
Class II Systems: Pumped/Dosed Soil Absorption Trenches () or Bed ()
Evapotranspiration Trenches () or Bed ()
Shallow Soil Absorption Trenches () or Bed () Other: _____

No. of Lines: 3 Length (in feet) of Each: 80'
Width of Trenches: 36 inches/feet Depth to Bottom of Field: 30 inches
If Bed, Dimensions (in feet): _____ If Chamber System, Name: _____, No. of Units: _____
Approved and Adequate Materials Used? Yes (x) No () Size Equates to 1200 sq ft of SGF
Distance (in feet) of System to: Dwelling Private () Public ()
Water Source: _____ Property Line: > 100'

Remarks: _____

GPS: N39 30 21.1 W78 34 12.8

An inspection indicates that
The sewage disposal system
Described above

DOES MEET ☐

DOES NOT MEET ☐ or


CANNOT BE DETERMINED TO

MEET ☐ the minimum standards
Established by the West Virginia
Bureau of Public Health.

To correct a health hazard,
Modifications to existing systems
May be done to improve part of a
System. Such modifications may
Not be able to be designated as
a Does meet system since
Inadequate information is known.

Although many factors
Contribute to the successful
Functioning of a sewage disposal
System, this office recommends
Water conservation and
Maintaining an even usage of
Water throughout the week.

Visit Date(s): _____



FINAL INSPECTION DATE: 5/21/2007

SANITARIAN: *Walter Fields*