

SS-183
Rev. 3/79

SMALL SEWAGE DISPOSAL INSTALLATION PERMIT

PERMIT NO. ST-14-96-422To: John FoldsAddress: 2410 OAKMONT CT.
OAKTON, VA 22124

You are hereby issued a permit to install
a small sewage disposal system consisting of a septic tank and drain field
and located at CARON GLEN SECT # 4 LOT # 15

This small sewage disposal system shall meet the following specifications:

1. Septic Tank

- a. Shall be made of precast concrete and not less than 1000
gallon capacity.

2. Soil-Absorption System

- a. Shall consist of 4 distribution lines 4" in diameter.
b. Each distribution line shall be 100 100 100 100
feet in length
c. Each trench shall be 24 inch width with ZERO slope on trench bottom
and ZERO slope on each distribution line.
d. No trench shall be more than 24 inches deep.
e. Total soil-absorption area in trench bottoms shall be 1200 sq. ft.
f. Filter material shall be gravel and not greater than 1/2 - 2 1/2
inches in diameter.
g. Filter material under each line shall be not less than 6 inches
deep and not less than 2 inches over each distribution line.
h. Filter material shall be covered with paper prior to backfilling.
i. Trenches shall be backfilled at least 6" above ground surface to provide
for settling of backfill.

3. Other Small Sewage or Excreta Disposal Systems (Name the type system to be used,
then use back of sheet to describe the details of the system.) DIVERSION
WORK IF NEEDED4. Special Requirements

- a. Small sewage and excreta disposal systems shall be located at least 10 ft.
from any property line and a minimum of 20 ft. from any stream or roadside cut.
b. Septic tanks shall be located at least 10 ft. and excreta disposal systems
a minimum of 20 ft. from building foundation.
c. Septic tanks shall be located a minimum of 50 ft. and soil-absorption systems
and excreta disposal systems a minimum of 100 ft. from any ground water supply
or cistern.
5. This permit is not transferable and automatically expires 12 months after date
of issue.
6. The applicant or his agent must notify this department, phone 822-5111 at
least 72 hours before the system is ready for inspection.
7. All small sewage and excreta disposal systems must be inspected and approved
prior to being covered with earth or otherwise put into service. Any applicable
system or part thereof covered before being inspected shall be uncovered at the
direction of the SANITARIAN.
8. This permit is NULL AND VOID when official inspection reveals conditions
are different than those stipulated in this permit or if facts later become known
that a health hazard would result by the installation of this system.

6-26-76
Date of Issue
Hampshire County Health Dept.
66 N. High Street Room #3
Romney, WV 26757
Phone: 304-822-5111
Health Department

J. Linder
Name
Sanitarian
Title

Please draw a sketch of the property showing existing or proposed well location, location of structures, existing proposed sewage system within 200 feet of well location, slope of site and lot dimensions. Locate animal pens, barn yards or any other factors which can be a possible source of contamination for the water supply.

☒ House
☐ Soil Absorption Line
☐ Trees

☒ Water Supply
☒ Dir. of Ground Slope
☒ Septic Tank

☒ Percolation Test Site
☒ Property Line
☒ Mobilehome

Capon Glen
Lot # 15

PART III
SEWAGE DISPOSAL SYSTEM INFORMATION

☒ Install ☐ Modify
☒ Septic Tank ☒ Absorption Field ☐ Holding Tank ☐ Pit Privy ☐ Vault Privy
☐ Chemical/Composting Toilet ☐ Alternate System (attach detailed plans)
 Other _____

DESCRIPTION OF PROPOSED SYSTEM:

Septic Tank: Capacity 1000 Material concrete Nearest Prop. Line 100'
 Absorption Field: 900 Sq. ft. with 3 lines and 120' long
 Pipe ASTM No. granular Nearest Property Line 100'
 Type of Water Supply: well Area Suitable for Absorption Field: _____ Sq. ft.
 1x-foot hole free of water or solid rock? ☒ Yes ☐ No

PERCOLATION TEST:

TEST HOLE: #1 110 minutes #2 95 minutes #3 100 minutes #4 120 minutes
 Total minutes 425, divided by 4 = 106.25 average time for water to fall one inch.
 Test done on May 22 (date) using approved procedures outlined in the Design Standards.

Signed: [Signature]

[Signature]
 Signature of Installer

54-87-0268
 Certification No.

May 10 26
 Date