

REQUEST FOR SITE APPROVAL

To: Hardy County Health Department, Moorefield, WV

From: Name: EMORY MILLER / Phone 410-658-2471

Address 149 Connelly Rd Rising Sun MD 21911

RE: Property Location LOT 10 Fawn Grove Sub.

Request is hereby made for a site investigation to determine the suitability of the subject property as a site for small sewage system indicated below:

☒ Septic System ☐ Pit Privy ☐ Vault Privy ☐ Other

The results of a percolation test conducted in accordance with the requirements of Design Standards for Small Septic Tank Systems follows:

Depth of test holes: #1 22, #2 22, #3 22, #4 22 inches.

Time for water to fall 6 inches in test hole	#1	<u>285</u>	minutes
	#2	<u>275</u>	minutes
	#3	<u>285</u>	minutes
	#4	<u>300</u>	minutes
	Total	<u>1145</u>	minutes.

A test hole bored or dug 6 feet deep ☒ has ☐ has not been provided to help determine the depth to bedrock and ground water table.

On the back of this form a plot layout has been sketched showing the property lines and relative locations of buildings, water supplies, percolation test holes, six ft. hole, and other pertinent features.

I (we), the undersigned, certify that the information contained herein is correct and accurate to the best of my (our) knowledge. It is further understood that this form is not an application for a permit, and subsequent acceptance of this site by the designed health department does not constitute a permit to install a sewage system.

Owner's Signature Emory Miller / Date 6/22/06

Percolation test conducted by: Name: Nick High and Son LLC
Address: PG. Box 219 Old Fields WV


Date: 10/05/05 / Signature Kenneth M. High

For Health Department Use Only

This is to certify that the Hardy County Health Department reviewed the contents of this form and conducted a site visit on subject property. Based on the information provided it is the opinion of the undersigned that this site ☒ is ☐ is not suitable for the installation of the small sewage system indicated.

Signature and Title Willie Ann / Smith Date 4/18/06

47 min avg
400 gpf
per inch



pecial commissioners,
17 2005 AS