TEL: 831-724-5422 FAX: 831-724-3188

42 HANGAR WAY WATSONVILLE CALIFORNIA 95076 USA

Joseph Gali

57 Alpine Avenue

Los Gatos, CA 95030

Work Order #:

8060267

Reporting Date: June 18, 2018

Date Received:

June 6, 2018

Project # / Name:

None / 0 Old Smith Rd., Watsonville, CA

Water System #:

Sample Identification:

0 Old Smith Rd., Watsonville, CA, sampled 6/6/2018 10:30:00AM

Sampler Name / Co.:

Joseph Gali / Private Owner

Matrix:

Water

State

8060267-01				Drinking Water	Analysis	Date	
	Results	Units	RL	Limits 1	Method	Analyzed	Flags
-	420	mg/L	10	1000	SM2540C	06/12/18	
	ND	mg/L	1.0	45	EPA 300.0	06/16/18	
	38	mg/L	1.0	500	EPA 300.0	06/16/18	
	680	ug/L	50	300	EPA 200.7	06/12/18	
	250	ug/L	20	50	EPA 200.7	06/12/18	
	8060267-01	420 ND 38 680	Results Units   420 mg/L   ND mg/L   38 mg/L   680 ug/L	Results Units RL   420 mg/L 10   ND mg/L 1.0   38 mg/L 1.0   680 ug/L 50	Results Units RL Water Limits 1   420 mg/L 10 1000   ND mg/L 1.0 45   38 mg/L 1.0 500   680 ug/L 50 300	Results Units RL Water Limits 1 Method   420 mg/L 10 1000 SM2540C   ND mg/L 1.0 45 EPA 300.0   38 mg/L 1.0 500 EPA 300.0   680 ug/L 50 300 EPA 200.7	Results Units RL Limits 1 Method Analyzed   420 mg/L 10 1000 SM2540C 06/12/18   ND mg/L 1.0 45 EPA 300.0 06/16/18   38 mg/L 1.0 500 EPA 300.0 06/16/18   680 ug/L 50 300 EPA 200.7 06/12/18

RL - are levels down to which we can quantify with reliability, a result below this level is reported as "ND" for Not Detected. State Drinking Water Limits - as listed by California Administrative Code, Title 22.

<sup>\* -</sup> a \* in the left hand margin of the report means that particular constituent is above the California Drinking Water Limits.