

CHEROKEE COUNTY
HEALTH DEPARTMENT

1.07 Mo

	So.	PS	U
1. Topography & Landscape Position		/	
2. Soil Texture	/		
3. Soil Structure	/		
4. Soil Depth		/	
5. Distinctive Horizons	/		
6. Soil Drainage / Ground Water	/		
7. Available Space	/		
8. Site Classification		/	

SYSTEM DESIGNED FOR

Residence No. Bedroom 3 Mobile Home _____ No. _____ No. Bedroom _____
☒ Other Establishment Type _____ Basement ☒ Yes ☐ No
 Sewer Outlet Location _____ ☐ First Floor Level ☐ Basement Level
 Septic Tank 1000 Gallons _____
 No. Lines 3 Length 80 Width 3 Other _____
 Source of Water Supply well Distance From Septic Tank System 100
 Remarks Big ditch is 15-22' deep on south side
and runs across yard

None. S: SUITABLE, P: PROVISIONALLY SUITABLE, U: UNSUITABLE

NOTICE: This permit is issued to permit all the provisions of this permit and its conditions concerning the design, installation, operation and use of mobile disposal systems in Charlotte County, North Carolina, to be subject to the provisions of Article III of the Central States Local Governmental Code, Chapter 150, which is hereby incorporated by reference into this permit. Any person is permitted to view this permit and make any use of this system, or the residue of the system, other than that which is specifically stated in this permit. This permit is valid only for the use of any disposal system and does not constitute the equipment of the permit and the information I have provided is accurate to the best of my knowledge.

Signature: James C. Brown Date: 9/26/94

Print the name of the waste management system to be installed under this permit: LOT APPROVED (For Disapproval) (For Renewal) (For Extension)

Signature: [Signature] Date: 9/26/94

Print the name of the waste management system to be installed under this permit: LOT APPROVED (For Disapproval) (For Renewal) (For Extension)


DISTANCE REQUIREMENTS

- 5000 - Disposal System must be installed
- 5.5 feet from tide, foundation
 - 10 feet from property lines
 - 10 feet from water lines
 - 50 feet from basement/foundation
 - 15 feet from embankment or cuts
 - 50 feet from any stream
 - 100 feet from water supply

Gravel must be covered with untreated building paper or 2 in. of hay or straw.

Free Payment — yes — no

SKETCH OF SEPTIC SYSTEM LAYOUT



(PINK COPY FOR OWNER — GREEN COPY FOR CONTRACTOR — CANARY COPY FOR BUILDING INSPECTOR)

PHOTO LEFT

NEED OWNER: Bob & Judy Smith

Property Owner: WANCY PULSEN Imp. Permit No. 413795 DATE 4/13/95
Property Address: ROCK CREEK. AIGHT AT LADD BLVD Sub Division: CLARK'S LOT No. 1000

CHEROKEE COUNTY
HEALTH DEPARTMENT
CERTIFICATE OF COMPLETION

New Septic Tank System ☐ Existing Tank: Yes ☐ No ☐ Material: CONCRETE Manufacturer: CLARK'S Liquid Capacity: 1000

Built in Place Tank: Material: 480 Inside Dimensions: Length: 80 Width: 3 Liquid Depth: 2 Depth of Gravel: 1000

Nitrification Field: Square Footage: 480 Length of Lines: 80 Width: 3 No. Lines: 2 Depth of Gravel: 1000

Other Type Disposal: Repair To Existing System ☐ Existing Tank: Yes ☐ No ☐ Material: CONCRETE Manufacturer: CLARK'S Liquid Capacity: 1000

Nit. Field: Existing Square Footage: 480 Square Footage Added: 0 Total Sq. Footage: 480 No. Lines: 2 Length: 80 Width: 3

Residence ☒ No. Bedrooms: 2 Mobile Home ☐ No. Bedrooms: 0 Other Establishment ☐ Type: SEIP HL CUBES

Basement: Yes ☐ No ☐ Nearest Distance To: Water Supply: 100 Stream: 50 Foundation: 15 Property Line: 10 Installed By: SEIP HL CUBES

Remarks: REPAIR TO EXISTING SYSTEM

Approved Yes ☒ No ☐ Sanitation: REPAIR TO EXISTING SYSTEM NOTICE: This approval is issued subject to all the provisions of rules and regulations governing the design, installation, clearing, and use of septic disposal systems in Cherokee County, Section 190 of the North Carolina Administrative Code, and Chapter 134, Article 1 of the General Statutes of North Carolina. No permit is granted to make alterations in the design or use of this system other than the approved system of the authorized contractor, and the contractor shall not be held responsible for any damage to the system or to the property of the owner.

Not necessary for any given period of time.

(White copy - Owner Yellow copy - Electrical Inspector - Blue copy - Tax Office)

CR-0050