

# Hampshire County Health Department On-Site Sewage Disposal System Inspection Form

Permit # **ST-14-07-209 A**

Name of Owner: Greg Kinslow Installer: John Shreve  
Address: Box 1363, St. John, VI 831  
Property Location: Davey Ridge Tract 15 & 16 Lot Size: 11.05AC Acres  
Type of Facility: Residence Facility is: ☒ New ☐ Existing  
Design Loading in gpd/# Bedrooms: 3 Source of Water: Existing Well

## SEWAGE TANK COMPONENT

Capacity in Gallons: 1000 Material: precast concrete Manufacturer:   
Pump Chamber 1000gal (Both Top Sumps)  
Distances (in feet) of Tank to: Dwelling 32'  
Private ☒ Public ☐ Water Source: > 100' Property Line: > 100'

## ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Trenches ( ) or Bed ( ) Gravelless Pipe ( ), Diameter     In.  
Chamber Soil Absorption Trenches ( ) or Bed ( )  
Class II Systems: Pumped/Dosed Soil Absorption Trenches ( ) or Bed ( )  
Evapotranspiration Trenches ( ) or Bed ( )  
Shallow Soil Absorption Trenches ( ) or Bed (X) Other: LPP

No. of Lines: 5 Length (in feet) of Each: 60'  
Width of Trenches: 12 inches/feet Depth to Bottom of Field: 12 inches  
If Bed, Dimensions (in feet):     If Chamber System, Name:    , No. of Units:      
Approved and Adequate Materials Used? Yes (X) No ( ) Size Equates to 900 sq ft of SGF  
Distance (in feet) of System to: Dwelling 75' Private (X) Public ( )  
Water Source: >100' Property Line: 25'

Remarks:    

GPS: N39 16 22.5 W78 52 59.7

An inspection indicates that  
The sewage disposal system  
Described above

**DOES MEET X**

**DOES NOT MEET** ☐ or


**CANNOT BE DETERMINED TO**

**MEET** ☐ the minimum standards  
Established by the West Virginia  
Bureau of Public Health.

To correct a health hazard,  
Modifications to existing systems  
May be done to improve part of a  
System. Such modifications may  
Not be able to be designated as  
a Does meet system since  
Inadequate information is known.

Although many factors  
Contribute to the successful  
Functioning of a sewage disposal  
System, this office recommends  
Water conservation and  
Maintaining an even usage of  
Water throughout the week.

Visit Date(s):    



FINAL INSPECTION DATE: 11/28/2007

SANITARIAN: Sam May Jr