

**WV STATE DEPARTMENT OF HEALTH**  
Office of Environmental Health Services  
**ENVIRONMENTAL ENGINEERING DIVISION**

SW258

Steve, Diane Nace

**WELL COMPLETION REPORT**Rec'd  
11/03/89

Date(s) 10-2-3-4-5-89 County HAMPSHIRE Permit #: DW-14-09-90-75  
 Town: CARON BRIDGE Area Name/Location CARON BRIDGE SUB Lot #10 Sec H6  
 Well Owner: HARRY CATES Address: Box 289  
 Telephone Number: 304-856-2516 HIGHTON W. VA 26808  
 Well Driller: RANDAL C. MILLER Address: Box 186  
 Telephone Number: 304-738-3266 REDGELEY W. VA. 26753

**WELL LOG**

DEPTH IN FEET	FORMATIONS: KIND, THICKNESS, AND IF WATER BEARING	REMARKS:
0-13'	YELLOW SANDSTONE (UNCONSOLIDATED)	Type of Well: <u>DW</u> Drilling Method: <u>AIR ROTARY HAMMER</u>
13'	WHITE SANDSTONE (BEDROCK)	Well Diameter: <u>6 1/8"</u> Casing O.D.: <u>6 3/8"</u>
20'	WHITE SANDSTONE (CONSOLIDATED)	Well Depth: <u>665'</u> Date Completed: <u>10-5-89</u>
	CEMENT SET CASING	CASING: Length <u>21'</u> Feet Height above ground <u>1</u> Feet
315'	RED SANDSTONE (CONSOLIDATED)	<input checked="" type="checkbox"/> Steel GALV <input type="checkbox"/> Plastic <input type="checkbox"/> Cast Iron
322'	WHITE SANDSTONE (CONSOLIDATED)	Other _____ Type _____
340'	BLUE SANDSTONE (CONSOLIDATED)	
522'	BLUE SANDSTONE (WATER BEARING)	
621'	BLUE SANDSTONE (WATER BEARING)	
665'	BLUE SANDSTONE (CONSOLIDATED)	
	STOPPED DRILLING	

**PUMPING OR BAILING TEST**

DETAILS	#1	#2	#3
Static Water Level (Ft. Below Grade)	<u>490</u>		
Pumping Rate (GPM)	<u>5</u>		
Pumping Level (Ft. Below Grade)	<u>655</u>		
Duration of Test (In Hours)	<u>2</u>		
Recovery Time to Static Level (In Hours)	<u>4</u>		

**WELL HEAD**

Pitless Adapter: Type, Make, Etc. ROYER, CONDUIT TYPE  
 Well Cap: Type, Make, Etc. ROYER, CONDUIT TYPE  
 Well Seal: Type, Make, Etc. TO BE INSTALLED BY OWNER  
 Well Platform: TO BE INSTALLED BY OWNER  
 Length \_\_\_\_\_ Width \_\_\_\_\_ Thickness \_\_\_\_\_  
 Grouting: ☐ Yes ☒ No  
 All Public Water Supplies must be grouted.

I hereby certify that this well was drilled and constructed under my supervision, in compliance with all requirements of the referenced permit, and that this record is true to the best of my knowledge and belief.

RANDAL C. MILLER  
 Name  
MILLER BROS. DRILLING  
 Registered Business Name  
RANDAL C. MILLER  
 Signed

432  
 Certification No.  
10-5-89  
 Date

SS-17  
Rev 1-71WEST VIRGINIA  
SEPTIC TANK INSPECTION FORM

Health Department Installation Permit No. 7190-124  
 Name of Owner Harry W. Oats Steve, Diane Nace  
 Address 1111 W. 11th St. W.  
 Property Address #10 Cabin Top Bridge Rd

## DESCRIPTION &amp; NUMBER OF UNITS SERVED

Type Facility Served residential No. Water Closets \_\_\_\_\_  
 Lot Size \_\_\_\_\_ sq. ft. Area suitable for sewage disposal installation \_\_\_\_\_ sq. ft.  
 Source of Water Supply well No. Lavatories \_\_\_\_\_  
 No. Bedrooms 2 No. Showers or Tubs \_\_\_\_\_ No. Baths \_\_\_\_\_  
 No. Garbage Grinders no No. Automatic Washers ✓

## SEPTIC TANK

Material concrete Length \_\_\_\_\_ x Width \_\_\_\_\_ x Depth \_\_\_\_\_ = \_\_\_\_\_ cubic feet  
 Liquid Depth \_\_\_\_\_ ft. Liquid Capacity 1000 gal.  
 Distance to: Dwelling 60 Water Supply 85 Nearest Property Line 100

## SOIL ABSORPTION SYSTEM

Type Drain Line Material plastic Trench Width 36 Inches  
 Trench Depth 16.0 Inches Total Absorption area in Trench Bottom 1200 sq. ft.  
 Diameter of Drain Line 4 in Inches Type Filter Media gravel (80 mesh)  
 No. of Drain Lines \_\_\_\_\_ Depth Filter Media Under Drain Line 8-10 Inches  
 Length of Each Line 100, 100, 100, 100 ft. Depth Filter Media Over Drain Line 2 in.  
 Distance of Disposal Field to: (a) Dwelling 90  
 (b) Water Supply 75 (c) Nearest Property Line a (5 ft. min.)


An inspection of the septic tank system described herein disclosed that said system (MEETS, DOES NOT MEET) the minimum standards established by the West Virginia State Department of Health.

Date 9-29-89Sanitarian David D. Delp

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.

Steve & Diane Place



David Dwyer  
Sanitarian

