

Office of Environmental Health Services
ENVIRONMENTAL ENGINEERING DIVISION

WELL COMPLETION REPORT

Date(s) 7-14-06 County Hampshire Permit # DW1406377
 Town: Augusta Area Name/Location Latigo Run Lot 7
 Well Owner: Ronald & Julie Brookman Address: PO Box 670
Miller Brothers Drilling LLC
 Telephone Number: (304)822-4092 Augusta WV 26704
 Well Driller: Miller Brothers Drilling LLC Address: PO Box 670
 Telephone Number: (304)822-4092 Augusta WV 26704

WELL LOG

DEPTH IN FEET	FORMATIONS: KIND, THICKNESS, AND IF WATER BEARING	REMARKS:
0-27	Brown shale	Type of Well: <u>Drilled</u> Drilling Method: <u>Air rotary</u>
27-142	Blue shale	Well Diameter: <u>6 1/8"</u> Casing O.D.: <u>7"</u>
		Well Depth: <u>142'</u> Date Completed: <u>7-14-06</u>
		CASING: Length <u>40</u> Feet Height above ground <u>1</u> Feet
		☐ Steel ☒ Plastic ☐ Cast Iron
		Other _____ Type _____
		SCREEN
		☐ None Installed
		Type _____ Diameter _____
		Slot/Gauge _____ Length _____
		Set Between _____ Ft. and _____ Ft.

PUMPING OR BAILING TEST

DETAILS	#1	#2	#3
Static Water Level (Ft. Below Grade)	<u>45</u>		
Pumping Rate (GPM)	<u>60</u>		
Pumping Level (Ft. Below Grade)	<u>140</u>		
Duration of Test (In Hours)	<u>2</u>		
Recovery Time to Static Level (In Hours)			

WELL HEAD

Pitless Adapter: Type, Make, Etc. _____
 Well Cap: Type, Make, Etc. _____
 Well Seal: Type, Make, Etc. _____
 Well Platform: _____
 Length _____ Width _____ Thickness _____
 Grouting: ☒ Yes ☐ No
 All Public Water Supplies must be grouted.

I hereby certify that this well was drilled and constructed under my supervision, in compliance with all requirements of the referenced permit, and that this record is true to the best of my knowledge and belief.

Bobby Allred 602
 Name Certification No.
Miller Brothers Drilling LLC 7-14-06
 Registered Business Name
 Signed _____ Date _____

SW-257
Rev. 8/01WEST VIRGINIA
DEPARTMENT OF HEALTH AND HUMAN RESOURCES**PERMIT**

OWNER: Ronald & Julie Brookman and DRILLER Miller Bros. Drilling
are hereby issued a permit to construct a well located
at 50 E to Sol Shanholtz Rd. to Laticio Run S/D on right, Lot 7
(Construct, Modify or Abandon)

in accordance with Chapter 16, Article 1, Section 9 of the Code of West Virginia.

Date issued 6-15-06 [Signature] Sanitarian
Issuing Officer Title

Expires 6-15-07
Hampshire

Permit No. DW-14-06-377 [Signature] County Health Department

This permit is not transferable and any change of information submitted in application dated 6-14-06 will automatically render this permit invalid.

THIS PERMIT IS NOT APPLICABLE TO PUBLIC WATER SUPPLIES

Hampshire County Health Department On-Site Sewage Disposal System Inspection Form

Permit # ST-14-08-52

Name of Owner: Ronald & Julie Brookman Installer: Billy G. Hart

Address: 5152 Green Bridge Rd, Dayton, Md 21036

Property Location: Latigo Run Lot 7 Lot Size: 20AC Acres

Type of Facility: Residence Facility is: ☒ New ☐ Existing

Design Loading in gpd/# Bedrooms: 3 Source of Water: Well

SEWAGE TANK COMPONENT

Capacity in Gallons: 1000 Material: precast concrete Manufacturer:

Pump Chamber gal

Distances (in feet) of Tank to: Dwelling 22'

Private ☒ Public ☐ Water Source: > 200' Property Line: > 100'

ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Trenches () or Bed () Gravelless Pipe (), Diameter In.

Chamber Soil Absorption Trenches (X) or Bed ()

Class II Systems: Pumped/Dosed Soil Absorption Trenches () or Bed ()

Evapotranspiration Trenches () or Bed ()

Shallow Soil Absorption Trenches () or Bed () Other:

No. of Lines: 4 Length (in feet) of Each: 80'

Width of Trenches: 36 inches/feet Depth to Bottom of Field: 24 inches

If Bed, Dimensions (in feet): If Chamber System, Name: , No. of Units:

Approved and Adequate Materials Used? Yes (X) No () Size Equates to 1600 sq ft of SGF

Distance (in feet) of System to: Dwelling 30' Private (X) Public ()

Water Source: > 200' Property Line: > 100'

Remarks:

GPS: N39 20 42 W78 34 59.6

An inspection indicates that
The sewage disposal system
Described above

DOES MEET ☒ X

DOES NOT MEET ☐ or

CANNOT BE DETERMINED TO


MEET ☐ the minimum standards

Established by the West Virginia
Bureau of Public Health.

To correct a health hazard,
Modifications to existing systems
May be done to improve part of a
System. Such modifications may
Not be able to be designated as
a Does meet system since
Inadequate information is known.

Although many factors
Contribute to the successful
Functioning of a sewage disposal
System, this office recommends
Water conservation and
Maintaining an even usage of
Water throughout the week.

Visit Date(s):



FINAL INSPECTION DATE: 9/14/2007

SANITARIAN: Billy G. Hart