

150- Amber Oaks / Section

STATE OF TEXAS WELL REPORT for Tracking #100911

Owner:	Thousand Oaks Land, LTD	Owner Well #:	1
Address:	1710 W. 6th St. Austin, TX 78703	Grid #:	57-22-6
Well Location:	Amber Oaks Ranch / Lot #24 Burnet, TX 78611	Latitude:	30° 41' 05" N
Well County:	Burnet	Longitude:	098° 17' 00" W
		Elevation:	No Data
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Start Date: 11/22/2006 Drilling End Date: 11/22/2006

	Diameter (in.)	Top Depth (ft.)	Bottom Depth (ft.)
Borehole:	8	0	15
	6	15	400

Drilling Method: Air Hammer

Borehole Completion: Straight Wall

	Top Depth (ft.)	Bottom Depth (ft.)	Description (number of sacks & material)
Annular Seal Data:	0	20	4 of Portland

Seal Method: Slurry

Sealed By: Driller

Distance to Property Line (ft.): 50+

Distance to Septic Field or other
concentrated contamination (ft.): 100+

Distance to Septic Tank (ft.): No Data

Method of Verification: Landowner

Surface Completion: Surface Sleeve Installed

Water Level: No Data

Packers: Burlap 150', 140', 20'

Type of Pump: No Data

Well Tests: Jetted Yield: 60 GPM

	<i>Strata Depth (ft.)</i>	<i>Water Type</i>
Water Quality:	220 - 390	Ellenberger
		Chemical Analysis Made: No
	Did the driller knowingly penetrate any strata which contained injurious constituents?: No	

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **APEX Drilling, Inc.**
PO Box 867
Marble Falls, TX 78654

Driller Name: **Andrew J. Johnson** License Number: **54989**

Comments: **No Data**

Lithology: DESCRIPTION & COLOR OF FORMATION MATERIAL			Casing: BLANK PIPE & WELL SCREEN DATA		
<i>Top (ft.)</i>	<i>Bottom (ft.)</i>	<i>Description</i>	<i>Dia. (in.)</i>	<i>New/Used</i>	<i>Type Setting From/To (ft.)</i>
0	3	Top Soil	4.5"	(5"OD) New	PVC +2' to 200' Sch40
3	10	Tan Limestone	4.5"	(5"OD) New	Slotted PVC 200' to 240' .035
10	45	Grey-Tan Dolomite	4.5"	(5"OD) New	PVC 240' to 360' Sch40
45	105	White-Tan Dolomite	4.5"	(5"OD) New	Slotted 360' to 400' .035
105	400	Pink-White Dolomite			
220	235	H2O			
385	390	H2O			

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 334-5540