

ATTENTION OWNER: Confidentiality
Privilege Notice on Reverse Side

STATE OF TEXAS
WATER WELL REPORT

1) OWNER: CARTER, ROBERT B. ADDRESS: 105 N. LLANO CITY: FREDERICKSBURG STATE: TX ZIP: 78624-

2) ADDRESS OF WELL:

County: MASON

GRID # 56-23-7

Street or RFD: 1 MI S FROM FM 2389 ON SCHEP CK RD; .2 MI E ON EMETH RD; .1 MI N/E IN PASTURE

City, State, Zip code: TX

3) TYPE OF WORK: NEW WELL

4) PROPOSED USE: DOMESTIC

If Public Supply well, were plans submitted to the TNRCC?

6) WELL LOG: 20407

DIAMETER OF HOLE

7) DRILLING METHOD:

8) BOREHOLE COMPLETION:

DATE DRILLING:	DIAMETER	FROM	TO	AIR ROTARY/HAMMER	OPEN HOLE	IF GRAVEL...	FROM	FT. TO	FT.
STARTED: 11/16/00	9	0	23.5						
COMPLETED: 11/17/00	6.75	23.5	24.5						
	6	24.5	380						

CASING, BLANK PIPE, AND WELL SCREEN DATA:

DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
6	N	PVC CASING	+2	24.5	SCH 40

GEOLOGICAL DESCRIPTION:

FROM	TO	DESCRIPTION
0	2	TOPSOIL
2	14	LIGHT Limestone-GRAY CLAY
14	17	GRAVEL
17	140	SANDY Limestone-GRAY Limestone-BROWN
140	190	SANDY Limestone-GRAY
	200	LIGHT SANDSTONE-BROWN
	220	SANDSTONE-BROWN SANDSTONE-RED
220	380	SANDSTONE-RED

9) CEMENTING DATA:

Cemented from	No. of Sacks Used
0 FT. TO 24 FT.	4
FT. TO FT.	
Method used: GROUT	
Cemented by: LYNN HOY	
Distance to septic field lines: ft.	
Method of verification of above distance:	

10) SURFACE COMPLETION:
PITLESS ADAPTER USED

11) WATER LEVEL:

STATIC LEVEL	: 10 FT.	DATE: 11/17/00
ARTESIAN FLOW:	GPM.	DATE:

12) PACKERS:	TYPE	DEPTH

13) TYPE PUMP:

SUBMERSIBLE
DEPTH TO PUMP: 200

14) WELL TEST:

JETTED
YIELD: 100+ GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY:

TYPE OF WATER: GOOD
NO STRATA OF UNDESIRABLE WATER PENETRATED

CHEMICAL ANALYSIS MADE

530 T.D.S.

COMPANY NAME: VIRDELL DRILLING INC.
ADDRESS: 111 E. GRAYSON ST.

WATER WELL DRILLER'S LICENSE NO.: 1900 4071 WPKL
CITY: LLANO STATE: TX ZIP CODE: 78643

FOR TWC USE ONLY
WELL NO. _____
LOCATED ON MAP _____

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 15 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed)

Lynn Hoy
(LICENSED WATER WELL DRILLER)

(signed)

(REGISTERED DRILLER TRAINEE)