

Per Request

B. Mark Smith #001
Name B. W. Smith Well Drilling Certification No.
Registered Business Name
Signed [Signature] Date 9/18/01

SS 77 7/98

STATE OF WEST VIRGINIA

INSPECTION TO BE
PRINTED OR TYPED

HEALTH DEPARTMENT

Permit No.: ST-14-99-281County: HamshireON-SITE SEWAGE DISPOSAL SYSTEM
INSPECTION FORM

Tax Map: _____ Parcel #: _____

County Road: _____

Name of Owner: Melbourne Corp Installer: D. J. K. dewell
 Address: P.O. Box 567 Capm Bridge, WV
 Property Location: Potomac Land Co LOT #14
 Type of Facility: House Facility is: New ☒ Existing () Lot Size: 2.0 Sq. Ft./Acres
 Design Loading in gpd/No. Bedrooms: 2 BR Source of Water Supply: well

SEWAGE TANK COMPONENT

Capacity in Gallons: 1000 Material: concrete Manufacturer: J. S. 11
 Distances (in feet) of Tank to: Dwelling: 10' Private ☒ Public () Water Source: 50' Property Line: 100'
to 50'

ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Absorption Trenches () or Bed () Gravelless Pipe ☒, Diameter: 10 inches
 Chamber Soil Absorption Trenches () or Bed ()
 Class II Systems: Pumped/Dosed Soil Absorption Trenches () or Bed () Evapotranspiration Trenches () or Bed ()
 Shallow Soil Absorption Trenches () or Bed () Other: _____


No. of Lines: 2 Length (in feet) of Each: 100, 100, 100
 Width of Trenches: 24 inches/feet Depth to Bottom of Field: 24-36 inches
 If Bed, Dimensions (in Feet): _____ If Chamber System, Name: _____ No. of Units: _____
 Approved and Adequate Materials Used? Yes ☒ No () Size Equates to: 900 Square Feet of Standard Gravel Field.
 Distances (in feet) of System to: Dwelling: 10' Private ☒ Public () Water Source: 100' Property Line: 100'
to 60'
 marks: _____

An inspection indicates that the sewage disposal system described above
DOES MEET ☒,
DOES NOT MEET (),
CANNOT BE DETERMINED TO MEET () the minimum standards established by the West Virginia Bureau of Public Health.

To correct a health hazard, modifications to existing systems may be done to improve part of a system. Such modifications may not be able to be designated as a does meet system since inadequate information is known.

Although many factors contribute to the successful functioning of a sewage disposal system, this office recommends water conservation and maintaining an even usage of water throughout the week.

Sketch of Installation with Triangulation or Distance to Specific Landmarks:



NOT TO SCALE

Visit Date(s): 4-9-89Final Inspection Date: 4-7-00Sanitarian: J. L. Linder