

WOODARD SEPTIC SERVICE, LLC
PO Box 441
Axtell, TX 76624

Phone: (254) 863-5137

woodardseptic@aol.com

To: Leo Dennis
4150 Lake Felton Pkwy
Waco, TX 76705

Printed: 7/26/2019
Site: 4150 Lake Felton Pkwy
Waco, TX 76705
(254) 863-5118

Permit #: 8862

Customer ID: 235

Agency: Waco-McLennan County Public Health District
County: McLennan Sub:
Mfg / Brand: - Hoot
Treatment Type: Aerobic
Disposal: Surface Application

Contract Dates: 3/12/2019 - 3/12/2020

Scheduled Date 7/12/2019

Inspection 1 of 3

Service Type: Scheduled Inspection

☒ This counts as a type of "Scheduled Inspection"

Visit Date: 7/10/2019

Entered By: _

Method: Grab

Technician: Woodard, Nealy W.

☒ Copy emailed to the Agency
Agency Emailed: 7/11/2019

Maint. Provider: Woodard, Nealy W.

Aerators: Operational

Sludge Levels

Filters: Operational

Irrigation Pumps: Operational

Disinfection Device: Operational

For Tank 3: 6-7"

Chlorine Supply: Operational

Chlorine Residual: .0

Tank Lid / Riser: Secured

Electric Circuits: Operational

Distribution System: Operational

Sprayfield Veg: Operational

Alarm: Operational

Comments

☒ **Service Completed**

Diaphragm kit is going out. Call for repair

Add chlorine soon- Technician Secured the Tank Lid or Riser prior to leaving location. - Copy emailed to the customer on 7/26/2019.

Insp ID #: 19195

Provider: Nealy Woodard, MP 148, OS 6074
Owner-Woodard Septic
254-863-5137

Technician: Nealy Woodard, MP 148, OS 6074
Owner-Woodard Septic
254-863-5137

License #: 148

Expires: 8/31/2020

License #: 148

Expires: 8/31/2020