

STATE OF TEXAS WATER WELL REPORT

1) OWNER: LANGE, CHARLES ADDRESS: 420 E. ORCHARD CITY: FREDERICKSBURG STATE: TX ZIP: 78624-
2) LOCATION OF WELL: County: GILLESPIE 1.9 miles in S direction from SALT BRANCH RD. on Link Rd.; 300'
East in pasture

LEGAL DESCRIPTION

SEE ATTACHED MAP

3) TYPE OF WORK: NEW WELL

4) PROPOSED USE: DOMESTIC

5) DRILLING METHOD: AIR ROTARY/HAMMER

6) WELL LOG: 92124

DIAMETER OF HOLE

DIAMETER

FROM

TO

8.75

0

65.5

6

65.5

190

7) BOREHOLE METHOD:

OPEN HOLE

IF GRAVEL...

FROM

FT. TO

FT.

FROM

FT. TO

FT.

DATE DRILLED: 09/01/92

GEOLOGICAL DESCRIPTION:

FROM	TO	DESCRIPTION
0	1	TOPSOIL
1	65	LIMESTONE-WHITE
"	"	LIMESTONE-BROWN
"	"	VOID
65	175	LIMESTONE-GRAY
"	"	LIMESTONE-WHITE
"	"	LIMESTONE-BROWN
175	190	LIMESTONE-GRAY
190		SHALE-GRAY

8) CASING, BLANK PIPE, AND WELL SCREEN DATA:

DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
6"	N	PVC CASING	+2	65.5	SCH 40

9) CEMENTING DATA:

Cemented from 0 FT. TO 10 FT.
55.5 FT. TO 65.5 FT.

Method used: GROUT

Cemented by: VIRDELL DRILLING INC

10) SURFACE COMPLETION:

APP. ALTER. PROCD.

11) WATER LEVEL:

STATIC LEVEL : 120 FT. DATE: 09/01/92

ARTESIAN FLOW: GPM. DATE:

12) PACKERS:

TYPE

DEPTH

6" BELL PACKER

65.5

13) TYPE PUMP:

SUBMERSIBLE

DEPTH TO PUMP: 180'

14) WELL TEST:

ESTIMATED

YIELD: 2

GPM WITH

FT DRAWDOWN AFTER

HRS

15) WATER QUALITY:

TYPE OF WATER: GOOD

DEPTH OF STRATA: 135'

NO CHEMICAL ANALYSIS MADE

NO STRATA OF UNDESIRABLE WATER PENETRATED

COMPANY NAME: VIRDELL DRILLING INC.

WATER WELL DRILLER'S LICENSE NO. 1900-W 240-W FOR TDWR USE ONLY

ADDRESS: 111 E. GRAYSON ST.

CITY: LLANO

STATE: TX ZIP CODE: 78643

WELL NO.

LOCATED ON MAP

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 12 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed)

(LICENSED WATER WELL DRILLER)

(signed)

(REGISTERED DRILLER TRAINEE)