

SUBDIVISION: 1000 BLOCK / SECTION: 10 LOT: 11/8/93 DATE: 10/12 STB: 1250 GALLONS: PT
 SEPTIC TANK: 1250 GALLONS: PT PUMP MAKE: Model SERIAL NO: 900 SQUARE FEET: 36 TRENCH WIDTH: 36 TRENCH BOTTOM DEPTH: 30
 NITRIFICATION FIELD: 1 FIELDS: 900 LINEAR FEET: 300 LINEAR FEET: 300 MAX TRENCH BOTTOM DEPTH: 30
 NO LINES: 3 TRENCH WIDTH: 36 TRENCH BOTTOM DEPTH: 30

COMMENTS: 1) KEEP SYSTEM MINIMUM 15' FROM BASEMENT, 10' FROM PROPERTY LINE, 100' FROM WELL
2) INSTALL LINES ON CONTOUR, NO DEEPER THAN 30" 9' APART ON CENTER
INITIAL SITE SKETCH

AS BUILT SKETCH

SYSTEM INSTALLED ACCORDING TO INITIAL SITE SKETCH

Water Supply: ☒ Individual ☐ Community ☐ Public
 House/Mod. Home ☒ Mobile Home ☐ Business ☐ Other
 No. Bedrooms: 3 No. Bathrooms: 2 1/2 No. Employees: 0
 Basement w/plumbing ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing

Comments:

Installed by: JAMES HUDLER date: 7/27/94
 Certificate of Completion by: STEVE HEXICK date: 7/27/94
 Operation Permit by: STEVE HEXICK date: 7/27/94
 OWNER COPY (FINAL): YELLOW
 INSPECTION COPY (FINAL): GREEN
 HEALTH DEPT. COPY: WHITE

I hereby certify that the above information is true and correct to the best of my knowledge and belief.
 Signature of Inspector _____
 Date _____
 Address _____
 Permit Date _____
 PERMIT TO INSTALL SEPTIC TANK
 MOORESVILLE Phone NO 3-1271
 IREDELL COUNTY HEALTH DEPARTMENT
 IR 3-1271