



Hampshire County Health Department

HC 71, Box 9

Augusta, WV 26704

Nursing: (304) 496-9640 Environmental: (304) 496-9641

Fax: (304) 496-9650

**Hampshire County Planning Commission
PO Box 883
Romney, WV 26757**

Dear Sirs:

This office has reviewed an application for James & Barbara Winter to approve lot 42 in High Mountain Orchard Subdivision, and further referenced as Tax District Romney, Tax Map 27, Parcel 71, Deed book 310, Page 625. This lot contains 3.001 acres. All lots require a percolation test and a sewage disposal area of 10,000 square feet where no development or structures other than the septic system shall be permitted. This lot is to be developed with a cistern and individual septic system to serve a single family dwelling.

Percolation test results are within limits as set forth by West Virginia CRS 16-1. Six foot soil observation holes indicate no restrictions due to water table or shallow bedrock within the designated sewage disposal area as noted on the Health Department subdivision application.

The application dated 11/2/2009, is hereby approved by the Hampshire County Health Department. Any changes or revisions to the lot, or subsequent plats, may make this approval null and void.

This approval is not permit for individual water systems or individual sewer systems. Applications for permits must be made separately to the Hampshire County Health Department.

Sincerely,

A handwritten signature in black ink, appearing to read "Terry Mayhew", is written over a horizontal line.

Terry Mayhew, RS

CC: James & Barbara Winter

[illegible]