

# Hampshire County Health Department On-Site Sewage Disposal System Inspection Form

Permit # ST-14-09-37

Name of Owner: Herbert R McGee Installer: Burkhart's Excavating  
Address: HC 87 Box 29, Yellow Spring, WV 26865  
Property Location: HG Brill Rd Lot Size: 13.5 Acres  
Type of Facility: Residence Facility is: ☒ New ☐ Existing  
Design Loading in gpd/# Bedrooms: 4 Source of Water: well

## SEWAGE TANK COMPONENT

Capacity in Gallons: 1000 Material: precast concrete Pump  
Distances (in feet) of Tank to: Dwelling 80'  
Private ☒ Public ☐ Water Source: >100' Property Line: >100'

## ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Trenches ( ) or Bed ( ) Gravelless Pipe ( ), Diameter     In.  
Chamber Soil Absorption Trenches (☒) or Bed ( )  
Class II Systems: Pumped/Dosed Soil Absorption Trenches ( ) or Bed ( ) LPP ( )  
Evapotranspiration Trenches ( ) or Bed ( )  
Shallow Soil Absorption Trenches ( ) or Bed ( ) Other:           

No. of Lines: 3 Length (in feet) of Each: 80's  
Width of Trenches: 36 inches/feet Depth to Bottom of Field: 24 inches  
Size Equates to 1200 sq ft of SGF  
Distance (in feet) of System to: Dwelling 98'  
Private (☒) Public ( ) Water Source: >100' Property Line: >100'

Remarks:

GPS: N39 12 08.0 W78 27 11.9

An inspection indicates that  
The sewage disposal system  
Described above  
DOES MEET ☒

DOES NOT MEET ☐ or

CANNOT BE DETERMINED TO

MEET ☐ the minimum standards  
Established by the West Virginia  
Bureau of Public Health.

To correct a health hazard,  
Modifications to existing systems  
May be done to improve part of a  
System. Such modifications may  
Not be able to be designated as  
a Does meet system since  
Inadequate information is known.

Although many factors  
Contribute to the successful  
Functioning of a sewage disposal  
System, this office recommends  
Water conservation and  
Maintaining an even usage of  
Water throughout the week.

Visit Date(s): 8/24/2012

FINAL INSPECTION DATE: 8/24/2012  
SANITARIAN:

*[Signature]* 32

