



Gabe Albarian &lt;gabrielalbarian@gmail.com&gt;

---

**FW: PG&E Application 111509339 4980 Hummingbird Ln, Mariposa**

---

**Gartner, Chris** <CSG8@pge.com>

Mon, Jun 6, 2016 at 8:50 AM

To: Gabe Albarian &lt;gabrielalbarian@gmail.com&gt;

Cc: Mike Farag &lt;mkfarag@roadrunner.com&gt;

Hi Gabriel,

I was able to field check the new subdivision. There is an existing PG&E distribution pole on the parcel to the south of the subdivision. I checked with Richard Seaman and there is an existing 50' PUE on the road that the PG&E pole is on. We can serve the new parcels from the existing pole. I think we can install 4 or 5 poles to serve the 4 parcels.

PG&E requires permanent load to serve prior to building line extensions to new parcels. If there is a well on one of the parcels we could give you a service. Please let me know where the meter location and load will be so we can proceed with the project. At that time PG&E will require a \$1500.00 engineering advance to proceed.

Thank you,

Chris Gartner

559-658-9607

---

**From:** Gabe Albarian [mailto:gabrielalbarian@gmail.com]**Sent:** Wednesday, June 01, 2016 11:21 PM**To:** Gartner, Chris

[Quoted text hidden]

[Quoted text hidden]