

LOT 2

STATE OF TEXAS WELL REPORT for Tracking #561120

Owner:	Stefanie Herdman	Owner Well #:	1
Address:	15209 Cascade Bluff Ct. Austin, TX 78738	Grid #:	57-35-7
Well Location:	2 Slate Rock Road Fredericksburg, TX 78624	Latitude:	30° 24' 26.75" N
Well County:	Gillespie	Longitude:	098° 43' 16.86" W
		Elevation:	No Data
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Start Date: **10/12/2020** Drilling End Date: **10/12/2020**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	
Borehole:	8	0	600	
Drilling Method:	Air Hammer			
Borehole Completion:	Filter Packed			
	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Filter Material</i>	<i>Size</i>
Filter Pack Intervals:	55	600	Gravel	
	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks & material)</i>	
Annular Seal Data:	0	6	Cement 3 Bags/Sacks	
	6	55	Bentonite 25 Bags/Sacks	
Seal Method:	Pressure		Distance to Property Line (ft.): 75+	
Sealed By:	Driller		Distance to Septic Field or other concentrated contamination (ft.): 150+	
			Distance to Septic Tank (ft.): 100+	
			Method of Verification: owner	
Surface Completion:	Pitless Adapter Used		Surface Completion by Driller	

Water Level:	No Data	
Packers:	No Data	
Type of Pump:	Submersible	Pump Depth (ft.): 500
Well Tests:	Estimated	Yield: 7 to 10 GPM

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 334-5540

LOT 3

STATE OF TEXAS WELL REPORT for Tracking #530636

Owner:	Brian Washburn	Owner Well #:	No Data
Address:	402 Plum Street Fredericksburg, TX 78624	Grid #:	57-35-7
Well Location:	Willow Creek Estates Fredericksburg, TX 78624	Latitude:	30° 24' 20.1" N
Well County:	Gillespie	Longitude:	098° 43' 15.2" W
		Elevation:	No Data
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Start Date: **12/18/2019** Drilling End Date: **12/18/2019**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	9.5	0	50
	6.75	50	65
	6	65	305

Drilling Method: **Air Hammer**

Borehole Completion: **Straight Wall**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks & material)</i>
Annular Seal Data:	1	3	Cement 0.5 Bags/Sacks
	3	50	Bentonite 3 Bags/Sacks

Seal Method: **Gravity**

Sealed By: **Driller**

Distance to Property Line (ft.): **180**

Distance to Septic Field or other concentrated contamination (ft.): **n/a**

Distance to Septic Tank (ft.): **n/a**

Method of Verification: **estimated**

Surface Completion: **Pitless Adapter Used**

Surface Completion by Driller

Water Level: **35 ft. below land surface on 2019-12-19** Measurement Method: **Sonic/Radar**

Packers: **none**

Type of Pump: **No Data**

Well Tests: **Jetted** Yield: **46 GPM**

	<i>Strata Depth (ft.)</i>	<i>Water Type</i>
Water Quality:	185 - 205	No Data
	214 - 225	No Data
	225 - 256	No Data

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which
contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **L & L Drilling Co.**
P.O. Box 217
Hye, TX 78635

Driller Name: **Gregory A. Smith** License Number: **1595**

Comments: **No Data**

Lithology:			Casing:						
DESCRIPTION & COLOR OF FORMATION MATERIAL			BLANK PIPE & WELL SCREEN DATA						
Top (ft.)	Bottom (ft.)	Description	Dia (in.)	Type	Material	Sch./Gage	Top (ft.)	Bottom (ft.)	
0	1	brown topsoil	6	Blank	New Plastic (PVC)	40 0.28	0	52	
1	61	brown sandy limestone with red layers							
61	113	brown & red sandstone							
113	185	brown & gray sandstone							
165	185	trace of water							
185	205	brown sandstone							
185	205	water 3 gpm							
205	214	brown & gray sandstone							
214	225	water 23 gpm							
214	256	gray sandstone							
225	256	water 20 gpm							
256	260	gray shale & clay							
260	305	gray sandstone with gray shale & clay layers							

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

**Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 334-5540**

Area Wells

STATE OF TEXAS WELL REPORT for Tracking #432222

Owner:	Jorge Canales	Owner Well #:	No Data
Address:	1905 Waterstone Aubrey, TX 76227	Grid #:	57-35-7
Well Location:	.7 mi. E of Hwy. 16 on FM 1323; 400' S Willow City, TX	Latitude:	30° 24' 39" N
		Longitude:	098° 43' 27" W
Well County:	Gillespie	Elevation:	No Data

Type of Work: **New Well** Proposed Use: **Stock**

Drilling Start Date: **9/16/2016** Drilling End Date: **9/16/2016**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	9.5	0	57
	6.75	57	58
	6	58	300

Drilling Method: **Air Hammer**

Borehole Completion: **Open Hole**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks & material)</i>
Annular Seal Data:	1	3	Cement 1 Bags/Sacks
	3	57	Bentonite 12 Bags/Sacks

Seal Method: **Poured**

Sealed By: **Driller**

Distance to Property Line (ft.): **No Data**

Distance to Septic Field or other
concentrated contamination (ft.): **No Data**

Distance to Septic Tank (ft.): **No Data**

Method of Verification: **No Data**

Surface Completion: **Pitless Adapter Used**

Water Level: **125 ft. below land surface on 2016-09-16**

Packers: **No Data**

Type of Pump: **Submersible** Pump Depth (ft.): **280**

Well Tests: **Jetted** Yield: **30 GPM**

STATE OF TEXAS WELL REPORT for Tracking #69441

Owner:	Ward Smith	Owner Well #:	No Data
Address:	638 RR 1323 Fredericksburg , TX 78624	Grid #:	57-35-7
Well Location:	.6 mi. E of Hwy. 16 on FM 1323; .4 mi. S in pasture TX	Latitude:	30° 24' 24" N
Well County:	Gillespie	Longitude:	098° 43' 32" W
Elevation:	No Data	GPS Brand Used:	Garmin III+
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Date:	Started: 10/24/2005 Completed: 10/24/2005
Diameter of Hole:	Diameter: 9 in From Surface To 50 ft Diameter: 6.75 in From 50 ft To 51 ft Diameter: 6 in From 51 ft To 220 ft
Drilling Method:	Air Hammer
Borehole Completion:	Open Hole
Annular Seal Data:	1st Interval: From 1 ft to 10 ft with 1 - cement (#sacks and material) 2nd Interval: From 10 ft to 50 ft with 11 - bentonite (#sacks and material) 3rd Interval: No Data Method Used: grout Cemented By: Taylor Virdell Jr. Distance to Septic Field or other Concentrated Contamination: n/a ft Distance to Property Line: 500+ ft Method of Verification: estimated Approved by Variance: No Data
Surface Completion:	Pitless Adapter Used
Water Level:	Static level: 28 ft. below land surface on 10/24/2005 Artesian flow: No Data
Packers:	
Plugging Info:	Casing or Cement/Bentonite left in well: No Data
Type Of Pump:	Submersible Depth to pump bowl: 200 ft
Well Tests:	Jetted Yield: 35 GPM with (No Data) ft drawdown after (No Data) hours
Water Quality:	Type of Water: good (540 ppm TDS) Depth of Strata: 120-220 ft Chemical Analysis Made: No Did the driller knowingly penetrate any strata which contained undesirable constituents: No

R-02983

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the log(s) being returned for completion and resubmittal.

Company Information: **Virdell Drilling Inc.**
111 E. Grayson St.
Llano , TX 78643

Driller License Number: **1900**

Licensed Well Driller Signature: **Taylor Virdell Jr.**

Registered Driller Apprentice Signature: **No Data**

Apprentice Registration Number: **No Data**

Comments: **No Data**

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #69441) on your written request.

Texas Department of Licensing & Regulation
P.O. Box 12157
Austin, TX 78711
(512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

From (ft) To (ft) Description
0 to 1 topsoil
1 to 35 brown clay & sandstone
35 to 110 brown sandstone
110 to 220 brown & red sandstone

Hick

CASING, BLANK PIPE & WELL SCREEN DATA

Dia.	New/Used	Type	Setting From/To
6"	New	PVC casing	+2 to 51 sch 40

R-02983

STATE OF TEXAS WELL REPORT for Tracking #314629

Owner: Fred B. Winter	Owner Well #: No Data
Address: 31 Day Lily Pl. The Woodlands , TX 77381	Grid #: 57-35-7
Well Location: 1063 RR 1323 Willow City , TX 78675	Latitude: 30° 24' 58" N
Well County: Gillespie	Longitude: 098° 43' 13" W
Elevation: No Data	GPS Brand Used: Garmin
Type of Work: New Well	Proposed Use: Domestic

Drilling Date: **Started: 3/15/2013
Completed: 3/15/2013**

Diameter of Hole: **Diameter: 9.75 in From Surface To 50 ft
Diameter: 6.75 in From 50 ft To 65 ft
Diameter: 6.00 in From 65 ft To 505 ft**

Drilling Method: **Air Hammer**

Borehole Completion: **Straight Wall**

Annular Seal Data: **1st Interval: From 1 ft to 3 ft with 0.5 cement (#sacks and material)
2nd Interval: From 3 ft to 50 ft with 4 bentonite (#sacks and material)
3rd Interval: No Data
Method Used: gravity grouted
Cemented By: L & L Drilling Co.
Distance to Septic Field or other Concentrated Contamination: 400 ft
Distance to Property Line: 900 ft
Method of Verification: estimated
Approved by Variance: No Data**

Surface Completion: **Pitless Adapter Used**

Water Level: **Static level: 217.5 ft. below land surface on 3/15/2013
Artesian flow: No Data**

Packers: **none**

Plugging Info: **Casing or Cement/Bentonite left in well: No Data**

Type Of Pump: **No Data**

Well Tests: **Jetted
Yield: 75 GPM with (No Data) ft drawdown after (No Data) hours**

Water Quality: **Type of Water: 1900 TDS, 17 grains hardness
Depth of Strata: 240, 281, 405 ft.
Chemical Analysis Made: Yes**

B-04177

Did the driller knowingly penetrate any strata which contained undesirable constituents: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the log(s) being returned for completion and resubmittal.

Company Information: **L & L Drilling Co.**
P.O. Box 217
Hye, TX 78635

Driller License Number: **1595**

Licensed Well Driller Signature: **Gregory A. Smith**

Registered Driller Apprentice Signature: **No Data**

Apprentice Registration Number: **No Data**

Comments: **No Data**

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #314629) on your written request.

Texas Department of Licensing & Regulation
P.O. Box 12157
Austin, TX 78711
(512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

From (ft) To (ft) Description
0 - 1 brown topsoil
1 - 14 brown clay
14 - 47 brown & white limestone
47 - 79 gray sandstone
79 - 158 brown sandstone
158 - 215 gray sandstone
215 - 240 gray & brown sandstone
240 - 263 red sandstone
263 - 281 gray sandstone
281 - 309 red sandstone
309 - 332 gray sandstone
332 - 505 red sandstone

CASING, BLANK PIPE & WELL SCREEN DATA

Dia.	New/Used	Type	Setting From/To
6	new	plastic solid	0 - 53 0.280

R-04177

240 - 245 water 4 gpm
281 - 305 water 6 gpm
405 - 505 water 65 gpm

jetted at 280' yield 15 gpm
jetted at 300' yield 25 gpm

R-04177

STATE OF TEXAS WELL REPORT for Tracking #33932

Owner:	Shawn Inman	Owner Well #:	No Data
Address:	110 N. Edison Fredericksburg , TX 78624	Grid #:	57-35-7
Well Location:	2864 Old Willow Rd. TX	Latitude:	30° 23' 34" N
Well County:	Gillespie	Longitude:	098° 42' 38" W
Elevation:	No Data	GPS Brand Used:	Garmin III
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Date: Started: 3/10/2004
 Completed: 3/10/2004

Diameter of Hole: Diameter: 9 in From Surface To 57.5 ft
 Diameter: 6.75 in From 57.5 ft To 58.5 ft
 Diameter: 6 in From 58.5 ft To 140 ft

Drilling Method: Air Hammer

Borehole
Completion: Open Hole

Annular Seal Data: 1st Interval: From 0 ft to 10 ft with 1 Cement (#sacks and material)
 2nd Interval: From 10 ft to 57.5 ft with 9 Bentonite (#sacks and material)
 3rd Interval: No Data
 Method Used: Grout
 Cemented By: Taylor Virdell Jr.
 Distance to Septic Field or other Concentrated Contamination: 100+ ft
 Distance to Property Line: 76' ft
 Method of Verification: measure
 Approved by Variance: No Data

Surface
Completion: Surface Sleeve Installed

Water Level: Static level: 38 ft. below land surface on 3/10/2004
 Artesian flow: No Data

Packers: No Data

Plugging Info: Casing or Cement/Bentonite left in well: No Data

Type Of Pump: Submersible
 Depth to pump bowl: 120 ft

Well Tests: Jetted
 Yield: 32 GPM with (No Data) ft drawdown after (No Data) hours

Water Quality: Type of Water: good (520 ppmTDS)
 Depth of Strata: 80 - 140 ft.
 Chemical Analysis Made: No
 Did the driller knowingly penetrate any strata which contained undesirable constituents: No

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the log(s) being returned for

Regulated by The Texas Department of Licensing and Regulation, P.O. Box 12157, Austin Texas 78711, 1-800-803-9202, 512-463-7880

<http://134.125.70.235/drillers-new/insertwellreportprint.asp>

3/11/2004
PL-00157
R-02687

completion and resubmittal.

Company Information: **Virdell Drilling Inc.
111 E. Grayson St.
Llano, TX 78643**

Driller License Number: **1900**

Licensed Well Driller Signature: **Taylor Virdell Jr.**

Registered Driller Apprentice Signature: **No Data**

Apprentice License Number: **No Data**

Comments: **No Data**

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner of the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #33932) on your written request.

**Texas Department of Licensing & Regulation
P.O. Box 12157
Austin, TX 78711
(512) 463-7880**

DESC. & COLOR OF FORMATION MATERIAL

CASING, BLANK PIPE & WELL SCREEN DATA

From (ft) To (ft) Description

**0 - 1 Topsoil
1 - 3 Brown Clay & Gravel
3 - 17 Brown Limestone
17 - 21 Sand
21 - 32 Brown & Gray Limestone
32 - 38 Brown Clay
38 - 80 Red & Gray Sandstone (Hickory)
80 - 140 Brown Large Grain Sandstone**

Dia. New/Used Type Setting From/To
6" N PVC +1.5 - 58.5 sch 40

Hick

Hick

R-00144

STATE OF TEXAS WATER WELL REPORT

1) OWNER: ACOSTA, LARUE ADDRESS: 9003 ROCK CLIFF RD. CITY: SAN ANTONIO STATE: TX ZIP: 78230-
2) LOCATION OF WELL: County: GILLESPIE .3 miles in EAST direction from HWY. 16 on FM 1323; 1 mile South on dirt rd.

LEGAL DESCRIPTION SEE ATTACHED MAP

KK 57387

3) TYPE OF WORK: NEW WELL 4) PROPOSED USE: DOMESTIC 5) DRILLING METHOD: AIR ROTARY/HAMMER

6) WELL LOG: 90098 DIAMETER OF HOLE 7) BOREHOLE METHOD:
DIAMETER FROM TO OPEN HOLE
8.75 0 32 IF GRAVEL... FROM FT. TO FT.
6 32 160 FROM FT. TO FT.
DATE DRILLED: 06/26/90

GEOLOGICAL DESCRIPTION: 8) CASING, BLANK PIPE, AND WELL SCREEN DATA:
FROM TO DESCRIPTION DIA NEW/USED DESCRIPTION FROM TO GAGE CASING SCREEN
0 1 TOPSOIL 6" N PVC CASING +2 32 SCH 40
1 5 CLAY-BROWN
5 15 CALICHE-WHITE/YELLOW
15 160 HICKORY Ss-RED/ BROWN

Heck

9) CEMENTING DATA:
Cemented from 0 FT. TO 32 FT.
Method used: GROUT
Cemented by: VIRDELL DRILLING INC

10) SURFACE COMPLETION:
PITLESS ADAPTER USED

11) WATER LEVEL:
STATIC LEVEL : 38' FT. DATE: 06/26/90
ARTESIAN FLOW: GPM. DATE:

12) PACKERS: TYPE DEPTH

13) TYPE PUMP: SUBMERSIBLE DEPTH TO PUMP: 120'
14) WELL TEST: ESTIMATED YIELD: 28 GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY: TYPE OF WATER: GOOD DEPTH OF STRATA: 38-160 NO CHEMICAL ANALYSIS MADE
NO STRATA OF UNDESIRABLE WATER PENETRATED

COMPANY NAME: VIRDELL DRILLING INC. WATER WELL DRILLER'S LICENSE NO. 1900-W 2940-W FOR TDWR USE ONLY
ADDRESS: 111 E. GRAYSON ST. CITY: LLANO STATE: TX ZIP CODE: 78643 WELL NO. _____
LOCATED ON MAP _____

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 12 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed) _____ (signed) _____

9/13/90 L4

GI-00026

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

For TWDB use only Well No. _____ Located on map _____ Received: _____

1) OWNER:
 Person having well drilled Raymond Wilke (Name) Address Llano Rt., Box 124 Fredericksburg, Texas (Street or RFD) (City) (State)
 Landowner Raymond Wilke (Name) Address Llano Rt., Box 124 Fredericksburg, Texas (Street or RFD) (City) (State)

2) LOCATION OF WELL: Gillespie County, 13 1/2 miles in N. E. direction from Fredericksburg, Texas (Town)
 (N.E., S.W., etc.)
 Locate by sketch map showing landmarks, roads, creeks, hiway number, etc. or Give legal location with distances and directions from adjacent sections or survey lines.
 Labor _____ League _____
 Block _____ Survey _____
 Abstract No. _____
 (NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section _____
 Map On Back Side North
 (Use reverse side if necessary)

3) TYPE OF WORK (Check):
 New Well Deepening Reconditioning Plugging

4) PROPOSED USE (Check):
 Domestic Industrial Municipal Test Well Other

5) TYPE OF WELL (Check):
 Rotary Driven Dug Jetted Bored

6) WELL LOG:
 Diameter of hole 7 3/4 in. Depth drilled 245 ft. Depth of completed well 28 1/2 ft. Date drilled 7-12-76
 All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	1	Top Soil
1	26	Sandy Orange Clay
26	114	Brown Sandstone
114	180	Red Sandstone
180	183	Brown Sandstone
183	221	Red Sandstone
221	224	Brown Sandstone
224	245	Red Sandstone

9) Casing:
 Type: Old _____ New Steel _____ Plastic _____ Other _____
 Cemented from _____ ft. to _____ ft.
 Diameter (inches) _____ Setting From (ft.) _____ To (ft.) _____ Gage _____

10) SCREEN:
 Type _____
 Perforated _____ Slotted _____
 Diameter (inches) _____ Setting From (ft.) _____ To (ft.) _____ Slot Size _____

7) COMPLETION (Check):
 Straight wall _____ Gravel packed _____ Other _____
 Under reamed _____ Open Hole _____

8) WATER LEVEL: 3 1/2 ft. below land surface Date 7-12-76
 Static level _____ ft. below land surface Date _____
 Artesian pressure _____ lbs. per square inch Date _____
 Depth to pump bowls, cylinder, jet, etc., _____ ft. below land surface.

11) WELL TESTS:
 Was a pump test made? Yes _____ No _____ If yes, by whom? _____
 Yield: 115 gpm with _____ ft. drawdown after _____ hrs.
 Bailer test 115 gpm with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ gpm
 Temperature of water _____

12) WATER QUALITY:
 Was a chemical analysis made? Yes _____ No _____
 Did any strata contain undesirable water? Yes _____ No _____
 Type of water? _____ depth of strata 224 ft.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME Eldon Ray Feller (Type or Print) Water Well Drillers Registration No. 1297
 ADDRESS 1107 E. Main Street (Street or RFD) P. O. Box 233 (City) Fredericksburg, Texas 78624 (State)
 (Signed) Eldon Ray Feller (Water Well Driller) Lone Star Pump Service (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.
 Additional instructions on reverse side.

WDB

9/30/76

