

WV Department of Health and Human Resources
Bureau of Public Health
Office of Environmental Health Services
ENVIRONMENTAL ENGINEERING DIVISION

SW258
10/01

WELL COMPLETION REPORT

Date(s) 10-05-05 County Hardy Permit # DW1605077
Town: McNeil Area Name/Location Ashton Woods Lot 219
Well Owner: Randy Sebero Address: 3 Country Court
Telephone Number: (540)657-4660 Stafford VA 22554
Well Driller: Miller Brothers Drilling LLC Address: PO Box 952
Telephone Number: (304)822-4092 Romney WV 26757

WELL LOG

DEPTH IN FEET	FORMATIONS KIND THICKNESS, AND IF WATER BEARING	REMARKS:
0-16	Yellow shale	Type of Well: <u>Drilled</u> Drilling Method: <u>Air rotary</u>
16-70	Blue shale	Well Diameter: <u>6 1/4"</u> Casing O.D.: <u>7"</u>
70-380	Blue sandstone	Well Depth: <u>380</u> Date Completed: <u>10-05-05</u>
		CASING: Length <u>80</u> Feet Height above ground <u>1.5</u> Feet
		<input type="checkbox"/> Steel <input checked="" type="checkbox"/> Plastic <input type="checkbox"/> Cast Iron
		Other _____ Type _____
		SCREEN
		<input checked="" type="checkbox"/> None Installed
		Type _____ Diameter _____
		Slot/Gauge _____ Length _____
		Set Between _____ Ft. and _____ Ft.

PUMPING OR BAILING TEST

DETAILS	#1	#2	#3
Static Water Level (Ft. Below Grade)	<u>220</u>		
Pumping Rate (GPM)	<u>15</u>		
Pumping Level (Ft. Below Grade)	<u>378</u>		
Duration of Test (In Hours)	<u>2</u>		
Recovery Time to Static Level (In Hours)			

WELL HEAD

Pitless Adapter: Type, Make, Etc. _____
Well Cap: Type, Make, Etc. _____
Well Seal: Type, Make, Etc. _____
Well Platform:
Length _____ Width _____ Thickness _____
Grouting: ☒ Yes ☐ No
All Public Water Supplies must be grouted.

I hereby certify that this well was drilled and constructed under my supervision, in compliance with all requirements of the referenced permit, and that this record is true to the best of my knowledge and belief.

Bobby Allred 602
Name Certification No.
Miller Brothers Drilling LLC 10-05-05
Registered Business Name
Bobby Allred _____
Signed Date

INSPECTION TO BE
PRINTED OR TYPED

STATE OF WEST VIRGINIA

HARDY County HEALTH DEPARTMENT

ON-SITE SEWAGE DISPOSAL SYSTEM
INSPECTION FORM

Permit No.: ST-16 - 05-040

Tax Map: Parcel #:

County Road:

County: HARDY

Name of Owner: Randy G. SEABRO & Mary SEABRO Installer: Billy HART
Address: 3 COUNTRY CT. STAFFORD VA 22554
Property Location: LOT 219 ASHTON Woods Subdivision McNEEL WV
Type of Facility: New Home Facility is: New ☒ Existing () Lot Size: 20.0 Sq. Ft./Acres
Design Loading in gpd/No. Bedrooms: 3 BDRM Source of Water Supply: WELL

SEWAGE TANK COMPONENT

Capacity in Gallons: 1000 Material: Concrete Manufacturer: Jelco
Distances (in feet) of Tank to: Dwelling: 70 Private ☒ Public () Water Source: 50' Property Line: 100'

ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Absorption Trenches () or Bed () Gravelless Pipe (), Diameter: _____ Inches
Chamber Soil Absorption Trenches ☒ or Bed ()
Class II Systems: Pumped/Dosed Soil Absorption Trenches () or Bed () Evapotranspiration Trenches () or Bed ()
Shallow Soil Absorption Trenches () or Bed () Other: _____

No. of Lines: 3 Length (in feet) of Each: 60' 60' 60'
Width of Trenches: 18-36 inches/feet Depth to Bottom of Field: 18-36 inches
If Bed, Dimensions (in Feet): _____ If Chamber System, Name: INFILTRATOR, No. of Units: 45

Approved and Adequate Materials Used? Yes ☒ No () Size Equates to: 900 Square Feet of Standard Gravel Field.

Distances (in feet) of System to: Dwelling: 40' Private ☒ Public () Water Source: 100' Property Line: 100'


Remarks: DISTANCES ARE TO CLEANOUT AS HOME WAS NOT ON LOCATION
AT Time of Inspection

An inspection indicates that the sewage disposal system described above
DOES MEET ☒.
DOES NOT MEET (),
CANNOT BE DETERMINED TO MEET () the minimum standards established by the West Virginia Bureau of Public Health.

To correct a health hazard, modifications to existing systems may be done to improve part of a system. Such modifications may not be able to be designated as a does meet system since inadequate information is known.

Although many factors contribute to the successful functioning of a sewage disposal system, this office recommends water conservation and maintaining an even usage of water throughout the week.

Sketch of Installation with Triangulation or Distance to Specific Landmarks:


Visit Date(s): April 14, 2005

Final Inspection Date: September 15, 2005

Sanitarian: Will Ours / Junt

