

# B&B WELL TESTING

P.O Box 21435  
Eugene, Oregon 97402  
(541) 484 7191

<b>Customer:</b>	<b>Colton Jacobson</b>	<b>Time</b>	<b>GPM</b>	<b>WSL</b>
		<b>12:15</b>	<b>20.0</b>	<b>13'</b>
<b>Address:</b>	<b>Horsepower Real Estate</b>	<b>12:30</b>	<b>20.0</b>	<b>21</b>
		<b>12:45</b>	<b>15.5</b>	<b>21</b>
<b>City:</b>	<b>Junction City, Oregon</b>	<b>1:00</b>	<b>15.5</b>	<b>21</b>
<b>Well Location:</b>	<b>94068 Oaklea</b>	<b>1:15</b>	<b>15.5</b>	<b>21</b>
		<b>1:30</b>	<b>15.5</b>	<b>21</b>
<b>City:</b>	<b>Junction City, Oregon</b>	<b>1:45</b>	<b>15.5</b>	<b>21</b>
<b>Test Started:</b>	<b>5-12-21 12:15 PM</b>	<b>2:00</b>	<b>15.5</b>	<b>21</b>
		<b>2:15</b>	<b>15.5</b>	<b>21</b>
<b>Test Completed:</b>	<b>5-12-21 4:15 PM</b>	<b>2:30</b>	<b>15.5</b>	<b>21</b>
<b>Bacteria Test:</b>	<b>Yes</b>	<b>2:45</b>	<b>15.5</b>	<b>21</b>
<b>Arsenic Test:</b>	<b>Yes</b>	<b>3:00</b>	<b>15.5</b>	<b>21</b>
<b>Nitrate Test:</b>	<b>Yes</b>	<b>3:15</b>	<b>15.5</b>	<b>21</b>
<b>Other:</b>	<b>Home Well Package</b>	<b>3:30</b>	<b>15.5</b>	<b>21</b>
<b>Comments:</b>	<b>Well (L129894) located approx. 40' NE of garage.</b>	<b>3:45</b>	<b>15.5</b>	<b>21</b>
		<b>4:00</b>	<b>15.5</b>	<b>21</b>
		<b>4:15</b>	<b>15.5</b>	<b>21</b>
<b>Technician:</b>	<b>Bert</b>	<b>Date: 5-19-21</b>		