

ATTENTION OWNER: Confidentiality
Please Notice on Reverse Side

STATE OF TEXAS
WATER WELL REPORT

R-00788

1) OWNER: JOHNSTON, WILBUR ADDRESS: RT. 3, BOX 257-A CITY: FREDERICKSBURG STATE: TX ZIP: 78624-

2) ADDRESS OF WELL:

County: GILLESPIE STATE WELL#
Street or RFD: PARADISE RANCH, #14
City, State, Zip code: TX

3) TYPE OF WORK: NEW WELL

4) PROPOSED USE: DOMESTIC

If Public Supply well, were plans submitted to the INRCC?

6) WELL LOG: 95032 DIAMETER OF HOLE 7) DRILLING METHOD: 8) BOREHOLE COMPLETION:

DATE DRILLING: 02/13/95

8.75" 0 330'

AIR ROTARY/HAMMER

GRAVEL PACKED

IF GRAVEL...

FROM 50 FT. TO 330 FT.
FROM FT. TO FT.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
5"	N	PVC CASING	+2	210	SDR 21
5"	N	PVC, CUSTOM SLOTTED	210	310	SDR 17
5"	N	PVC, CUSTOM SLOTTED	310	330	SCH 40

GEOLOGICAL DESCRIPTION:

FROM TO DESCRIPTION

0 1 TOPSOIL
1 7 CALICHE-WHITE/YELLOW
7 21 CLAY-BROWN
21 110 SHALE-GRAY LIMESTONE LEDGES
110 225 SHALE-GRAY LIMESTONE LEDGES SAND STREAKS
225 240 SHALE-GRAY LIMESTONE LEDGES SAND SHALE-RED
240 330 SAND SHALE-GRAY LIMESTONE LEDGES

9) CEMENTING DATA:

Cemented from No. of Sacks Used
0 FT. TO 50 FT. 6
FT. TO FT.

Method used: GROUT

Cemented by: TAYLOR VIRDELL JR.

Distance to septic field lines: ft.

Method of verification of above distance:

10) SURFACE COMPLETION:

PILESSE ADAPTER USED

11) WATER LEVEL:

STATIC LEVEL : 205 FT. DATE: 02/14/95

ARTESIAN FLOW: GPM, DATE:

12) PACKERS: TYPE DEPTH

13) TYPE PUMP:

SUBMERSIBLE

DEPTH TO PUMP: 300'

14) WELL TEST:

JETTED

YIELD: 20 GPM WITH

FT DRAWDOWN AFTER HRS

15) WATER QUALITY: 510 ppm TDS

TYPE OF WATER: 6000

NO STRATA OF UNDESIRABLE WATER PENETRATED

DEPTH OF STRATA: 220-330

NO CHEMICAL ANALYSIS MADE

COMPANY NAME: VIRDELL DRILLING INC.

ADDRESS: 111 E. GRAYSON ST.

WATER WELL DRILLER'S LICENSE NO.: 1900HPKL

CITY: LLANO

STATE: TX ZIP CODE: 78643

FOR TWC USE ONLY

WELL NO.

LOCATED ON MAP

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 15 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed)

David Virvell
(LICENSED WATER WELL DRILLER)

(signed)

(REGISTERED DRILLER TRAINEE)