CAMPbell

WV Department of Health and Human Resources Bureau of Public Health

Office of Environmental Health Services ENVIRONMENTAL ENGINEERING DIVISION

()

SW258 10/01

WELL COMPLETION REPORT

*		AAEFF	COMPLETION REPORT
Date(s) 3 - 4 - 08 C	ounty Han	i)shi	ire 14-8-099
^			TADOW KNOTIS - LOWER PLD
		100	Address 2821 Fry Rd.
Telephone Number: 301 - 834 - 9709			JEFFERSON MP 21755
Well Driller: B.L. Smith Well	Prilling My	wk Su	Address: P.O. Box 440
Telephone Number: 304 · 496 -			Springfield WV 06763
WELL LOG			
DEPTH IN FEET FORMATIONS: KIND, THICKNESS, AND IF WATER BEARING			REMARKS: DrivesHoe
0-75 Brown SHNe			Type of Well: Dom PST 16 Drilling Method: All DI
76-135 HAID Fray SHALE			Well Diameter: 6" Casing O.D.: 63/8
			Well Depth: 200 Date Completed: 2/4/08
136 WATER 1 G. P. M			CASING: Length 100 Feet Height above ground 1 Feet
131-145 Gray s/10h			Steel Plastic 🗆 Cast Iron
148 WATER 4 G.F.M.			Other
147-170 Gray Shale			Туре
170 WATER 15 G.P.M.			SCREEN
171-200 (-ray Stale			☐ None Installed
			Slot/Gauge Length
	all Hielenston		Set Between Ft. and Ft.
			1
PUMPING OR BAILING TEST	100 0 1	···	WELL HEAD
DETAILS #1 #2 #3		#3	Pitless Adapter: Type, Make, Etc.
Static Water Level (Ft. Below Grade)	100		Well Cap: Type, Make, Etc.
Pumping Rate (GPM)	20		Well Seal: Type, Make, Etc.
Pumping Level (Ft. Below Grade)	200		Well Platform:
Duration of Test (In Hours)		1	Length Width Thickness
Recovery Time to Static Level (In Hours)		+	Grouting: XYes
L			-
I hereby certify that this well was drilled and one is true to the best of my knowledge and belie		er my sup	pervision, in compliance with all requirements of the referenced permit, and that this record
			B. Mark Smith 001
			Name B. Mark Smith Name B. W. Smith Well Drilling Two: Registered Business Name
			Registered Business Name