



# IMPROVEMENT PERMIT

Beaufort County Health Department

Environmental Health Section

220 North Market St.

Washington NC 27889

Phone: 252-946-6048 Fax: 252-946-2074

For Office Use Only

Page 1 of 2

\*CDP File Number 44475 - 2

County ID Number: 7601003745

Evaluated For: NEW

PERMIT VALID UNTIL: 09 / 14 / 2021

\*NOTE TO INSPECTIONS DIVISION: Building Permits cannot be issued with only an Improvement Permit. ☐ Fill Sheet ☒ CA?

Applicant: Michael E. Humphreys  
Address: Petersgasse 42, Basel 4051  
City: Switzerland  
State/Zip: NC  
Phone #:

Property Owner: Michael E. Humphreys  
Address: Petersgasse 42, Basel 4051  
City: Switzerland  
State/Zip:  
Phone #:

Address Chambers Point Road  
Road # Belhaven NC 27810  
Township:

## Property Location & Site Information

Subdivision: The Trade Winds

Phase:

Lot: 33A

## Directions

Go toward end of Pamlico Beach Road--off Old Pamlico Road

Structure: SINGLE FAMILY  
# of Bedrooms: 3  
# of People:

\*Water Supply: PUBLIC

## Initial System

\*Site Classification: Suitable

## System Specifications

Saprolite System? ☐ Yes ☒ No

Design Flow: 3 6 0

Soil Group: 1

Soil Application Rate: 0 . 8

\*System Classification/Description:  
TYPE III B. SYSTEM W/SINGLE EFFLUENT PUMP

\*Proposed System: CONVENTIONAL

Minimum Trench Depth: 1 8 Inches

Maximum Trench Depth: 1 8 Inches

Fill Depth: Inches

Septic Tank: 1 0 0 0 Gallons

Pump Required: ☒ Yes ☐ No ☐ May Be Required

Pump Tank: 1 0 0 0 Gallons

Repair System Required: ☒ Yes ☐ No ☐ No, but has Available Space

## Repair System

\*Site Classification: Suitable

Soil Application Rate: 0 . 8

\*System Classification/Description:  
TYPE III B. SYSTEM W/SINGLE EFFLUENT PUMP

\*Proposed System: CONVENTIONAL

Minimum Trench Depth: 1 8 Inches

Maximum Trench Depth: 1 8 Inches

Fill Depth: Inches

Pump Required: ☒ Yes ☐ No ☐ May be Required

Pump Tank: 1 0 0 0 Gallons

No grading or construction activity is allowed in areas designated for system and repair without approval of Health Department.

\*Site Modifications An Authorization to Construct will be issued upon approval of final site plan by BCHD

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

\*Permit Conditions 1000gal septic tank, 1000gal pump tank, NEMA 4X control panel, effluent pump, supply line, pressure manifold and 3 (3' x 50') conventional drainlines as shown on permit; use soil cloth; Tankage located on Lot 3 and drainfield located on Lot 3A; supply located in easement

The Department and Local Health Department may impose conditions on the issuance and may revoke the permits for failure of the system to satisfy the conditions, the rules, or this article. This permit is subject to revocation if the site plan, plat, or intended use changes (NCGS 130A-335 (f)). The person owning or controlling the system shall be responsible for assuring compliance with the laws, rules, and permit conditions regarding system location, installation, operation, maintenance, monitoring, reporting, and repair (.1938(b)).

\*Authorized State Agent: 2018 - Hager, Matthew

Date of Issue: 09 / 14 / 2021

Owner/Applicant Signature: \_\_\_\_\_