




PERMIT NUMBER 0000

Pump

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO. 17180 334 37 95	TYPE OF ESTABLISHMENTS			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS. *THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
OWNER:	SR. NO. 1004	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: 3	NUMBER OF OCCUPANTS:	
APPLICANT'S ADDRESS:		WATER SUPPLY	WELL ☒ PUBLIC ☐	OTHER ☐	
PROPERTY ADDRESS/LOCATION:		TYPE OF WASTEWATER SYSTEM	INITIAL INSTALLATION ☒ Type 1, 2, 3, 4, 5, 6	REPAIR ☒ Subsurface drip irrigation	
		DESIGN FLOW:	360 gpm/day		
		LTAR:	3		
SUBDIVISION:		ABSORPTION AREA:	1200 sq. ft.		
LOT NUMBER: 3		TRENCH WIDTH:	3'		
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		TRENCH DEPTH:	12"		
		TRENCH SPACING:	9' on center		
		TOTAL TRENCH LENGTH:	400 ft.		
		NUMBER OF TRENCHES:	5		
		GRAVEL DEPTH:	12"		
		TANK SIZE:	1000 gal.		
		PUMP TANK SIZE:	1000 gal.		
		DISTRIBUTION DEVICE:	Pressure manifold		
					PERMIT VALID FOR: 5 YEARS YES ☒ NO ☐ NO EXPIRATION YES ☐ NO ☒

***** IMPROVEMENT PERMIT DATE: 6-11-07 *****

FOR: [Signature] Install French Drain above system
ISSUED BY: [Signature] Use 12" bucket - 24"-36" deep - 125' long

***** CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# 06379 *****

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.
(The wastewater system cannot be installed until authorization is signed)

Comments: This system is approved by Health Department and must be approved by the local health department to a depth of 1' minimum at 6' intervals

Date: 6-11-07 Environmental Health Specialist: [Signature] RS/DOC 7-8-08
Construction Authorization Addendum ☐ Yes ☒ No

OPERATION PERMIT

DATE:

SYSTEM INSTALLED BY:

ISSUED BY:

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION
AS REQUIRED BY RULE .1961