

Miller Drilling Co.

PUMP TEST REPORT

TESTING

Notes:

STANDING LEVEL AFTER TEST: 21.5 ft (5 min)

FINAL TEST RESULTS: Produced: 13 GPM for 4 hours on: 10/1/2020

Test Run By: Alex