

WV STATE DEPARTMENT OF HEALTH
Office of Environmental Health Services
ENVIRONMENTAL ENGINEERING DIVISION

SW258

WELL COMPLETION REPORT

Date(s) 1-13-92 County Hampshire Permit #: DW-14-11-92-146
Town: _____ Area Name/Location The Crossings, Lot 97
Well Owner: Peter & Nancy Juge Address: 313 N. Pitt Street
Telephone Number: 703/684-5947 Alexandria, VA 22314
Well Driller: High Point Drilling, Inc. Address: P.O. Box 190
Telephone Number: 804/725-1644 Charles Town, WV 25414

WELL LOG

DEPTH IN FEET	FORMATIONS: KIND, THICKNESS, AND IF WATER BEARING	REMARKS:
0-10	Dirt	Type of Well: <u>Green Mtn Rock</u> Drilling Method: <u>Rotary</u>
10-25	Rock & Sandstone	Well Diameter: <u>6 1/8</u> Casing O.D.: <u>6 5/8</u>
25-225	Green Mtn Rock	Well Depth: <u>305</u> Date Completed: <u>1-7-92</u>
225-235	Water	CASING: Length <u>21</u> Feet Height above ground <u>2</u> Feet
235-305	Green Mtn Rock	<input checked="" type="checkbox"/> Steel <input type="checkbox"/> Plastic <input type="checkbox"/> Cast Iron
		Other _____ Type _____
		SCREEN
		<input checked="" type="checkbox"/> None Installed
		Type _____ Diameter _____
		Slot/Gauge _____ Length _____
		Set Between _____ Ft. and _____ Ft.

PUMPING OR BAILING TEST

DETAILS	#1	#2	#3
Static Water Level (Ft. Below Grade)	<u>90</u>		
Pumping Rate (GPM)	<u>7</u>		
Pumping Level (Ft Below Grade)	<u>300</u>		
Duration of Test (In Hours)	<u>2 hrs</u>		
Recovery Time to Static Level (In Hours)	<u>1 hr</u>		

WELL HEAD

Pitless Adapter: Type, Make, Etc. _____
Well Cap: Type, Make, Etc. Rover Casting
Well Seal: Type, Make, Etc. _____
Well Platform: _____
Length _____ Width _____ Thickness _____
Grouting: ☒ No
All Public Water Supplies must be grouted.

I hereby certify that this well was drilled and constructed under my supervision, in compliance with all requirements of the referenced permit, and that this record is true to the best of my knowledge and belief.

Donald Giardina 502
Name Certification No.
High Point Drilling, Inc.
Registered Business Name
Donald J. Giardina 1-13-92
Signed Date