

Other Options

[Return to menu](#)
[Plot this site in State Library Digital Atlas](#)
[Plot this site in Google Maps](#)
 View scanned well log (7/7/2009 10:49:01 AM)

Section 7: Well Test Data

Total Depth: 280
Static Water Level: 180
Water Temperature:

Air Test *

10 gpm with drill stem set at 260 feet for 1 hours.
Time of recovery hours.
Recovery water level feet.
Pumping water level feet.

Time of recovery _ hours.
Recovery water level _ feet.
Pumping water level _ feet.

** During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.*

Addition	Block	Lot
----------	-------	-----

Section 8: Remarks

Section 9: Well Log

Geologic Source

Unassigned

[illegible]

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name:
Company: CAMP WELL DRILLING
License No: WWC-7
Date Completed: 4/29/2003

From	To	Diameter
0	280	6

Casing

From	To	Diameter	Wall Thickness	Pressure Rating	Joint	Type
-2	40	6				STEEL
30	280	4		160.00		PVC

Completion (Perf/Screen)

From	To	Diameter	# of Openings	Size of Openings	Description
235	275	4			FACTORY SLOTTED PVC

Annular Space (Seal/Grout/Packer)

From	To	Description	Cont. Fed?
0	25	BENTONITE SEAL	