

Form No. GWS-25

**OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES**

818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER **241517**

DIV. 1

WD 1

DES. BASIN

MD

APPLICANT

MELVIN & BERNICE LOVATA
10508 WCR 102
NUNN, CO 80648-

(970) 897-3182

APPROVED WELL LOCATION

WELD COUNTY

SW 1/4 SE 1/4 Section 26
Township 9 N Range 67 W Sixth P.M.

DISTANCES FROM SECTION LINES

300 Ft. from South Section Line

1505 Ft. from East Section Line

UTM COORDINATES

Northing:

Easting:

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not assure the applicant that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 45.11 acres described as that portion of the S 1/2 of the SE 1/4, Sec. 26, Twp. 9 N, Rng. 67 W, Sixth P.M., Weld County, more particularly described on the attached exhibit A.
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside not more than three (3) single family dwellings, the irrigation of not more than one (1) acre of home gardens and lawns, and the watering of domestic animals.
- 5) The maximum pumping rate of this well shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 7) This well shall be constructed not more than 200 feet from the location specified on this permit.

JD 6-6-02

APPROVED
JD2

State Engineer

Receipt No. 0492336A

DATE ISSUED

JUN 06 2002

By

EXPIRATION DATE

JUN 06 2004